



AGENDA

SPECIAL MEETING OF THE BOARD OF DIRECTORS LA PUENTE VALLEY COUNTY WATER DISTRICT 112 N. FIRST STREET, LA PUENTE, CALIFORNIA TUESDAY, DECEMBER 18, 2018 AT 5:30 PM

1. CALL TO ORDER

2. PLEDGE OF ALLEGIANCE

3. ROLL CALL OF BOARD OF DIRECTORS

President Rojas____ Vice President Escalera____ Director Barajas____

Director Hastings____ Director Hernandez____

4. PUBLIC COMMENT

Anyone wishing to discuss items on the agenda or pertaining to the District may do so now. The Board may allow additional input during the meeting. A five-minute limit on remarks is requested.

5. ADOPTION OF AGENDA

Each item on the Agenda shall be deemed to include an appropriate motion, resolution or ordinance to take action on any item. Materials related to an item on this agenda submitted after distribution of the agenda packet are available for public review at the District office, located at the address listed above.

6. APPROVAL OF CONSENT CALENDAR

There will be no separate discussion of Consent Calendar items as they are considered to be routine by the Board of Directors and will be adopted by one motion. If a member of the Board, staff, or public requests discussion on a particular item, that item will be removed from the Consent Calendar and considered separately.

A. Approval of Minutes of the Regular Meeting of the Board of Directors held on December 10, 2018.

B. Approval to Attend the Association of Ground Water Agencies AGWA – AGWT Annual Conference on Monday and Tuesday, February 11-12, 2019, in Ontario, CA.

7. FINANCIAL REPORTS

A. Summary of Cash and Investments for November 30, 2018.

Recommendation: Receive and File.

- B. Statement of District's Revenues and Expenses as of November 30, 2018.
Recommendation: Receive and File report.
- C. Statement of City of Industry Waterworks System's Revenues and Expenses as of November 30, 2018.
Recommendation: Receive and File Report.

8. ACTION/DISCUSSION ITEMS

- A. Consideration of Annual Cost of Living Adjustment for District Employees.
Recommendation: Board Discretion.
- B. Review and Approve the Proposed District Budget for Period Ending December 31, 2019.
Recommendation: Approve the Proposed District Budget for Period Ending December 31, 2019.

9. PROJECT ENGINEER REPORT

10. GENERAL MANAGER'S REPORT

11. OTHER ITEMS

- A. Upcoming Events.
- B. Correspondence to the Board of Directors.

12. ATTORNEY'S COMMENTS

13. BOARD MEMBER COMMENTS

- A. Report on Events Attended.
- B. Other Comments.

14. FUTURE AGENDA ITEMS

15. CLOSED SESSION

Public Employee Performance Evaluation.
Position: General Manager.

16. REPORT ON CLOSED SESSION

17. ADDITIONAL ACTION/DISCUSSION ITEM

Consideration of Compensation Adjustment and Extension of Employment Contract for the District's General Manager.

Recommendation: Board Discretion.

18. ADJOURNMENT

POSTED: Friday, December 14, 2018.

President William R. Rojas, Presiding.

Any qualified person with a disability may request a disability-related accommodation as needed to participate fully in this public meeting. In order to make such a request, please contact Greg B. Galindo, Board Secretary, at (626) 330-2126 in sufficient time prior to the meeting to make the necessary arrangements.

Note: Agenda materials are available for public inspection at the District office or visit the District's website at www.lapuentewater.com.



**MINUTES OF THE REGULAR MEETING OF
THE BOARD OF DIRECTORS OF THE
LA PUENTE VALLEY COUNTY WATER DISTRICT**

A regular meeting of the Board of Directors of the La Puente Valley County Water District was held on Monday, December 10, 2018, at 5:30 p.m. at the District office, 112 N. First St., La Puente, California.

Meeting Called to Order:

President Rojas called the meeting to order at 5:30 p.m.

Pledge of Allegiance:

President Rojas led the meeting in the Pledge of Allegiance.

Oath of Office:

Greg Galindo administered the Oath of Office to Directors' Cesar J. Barajas, John P. Escalera and Henry P. Hernandez; Board and Staff congratulated them.

Directors Present:

William Rojas, President; John Escalera, Vice President; Cesar Barajas, Director; David Hastings, Director and Henry Hernandez.

Staff Present:

Greg Galindo, General Manager; Gina Herrera, Office Manager; Roy Frausto, Engineering & Compliance Manager, Cesar Ortiz, Water Treatment & Supply Supervisor and Jim Ciampa, District Counsel.

Others Present:

Charlie & Susan Klinakis, Violet Lewis, Alicia Maes and Betty Escalera.

Public Comment:

Charlie Klinakis thanked the Board and Staff for their participation in the 2018 Annual La Puente Christmas Parade.

Adoption of Agenda:

President Rojas asked for the approval of the Agenda.

Motion by President Rojas, seconded by Director Hernandez, that the agenda be adopted as presented.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

Consent Calendar:

President Rojas asked for the approval of the Consent Calendar.

- A. Approval of the Minutes of the Regular Meeting of the Board of Directors held on November 13, 2018.
- B. Approval of the Minutes of the Regular Meeting of the Board of Directors held on November 20, 2018.

- C. Approval of District Expenses for the Month of November 2018.
- D. Approval of City of Industry Waterworks System Expenses for the Month of November 2018.
- E. Receive and File the District's Water Sales Report for November 2018.
- F. Receive and File the City of Industry Waterworks System's Water Sales Report for November 2018.
- G. Receive and File the Water Production Report for November 2018.

Motion by Vice President Escalera, seconded by President Rojas, to approve the Consent Calendar as presented.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

Action/Discussion Items:

A. Consideration of Rescheduling the December 24, 2018, Regular Board of Director's Meeting. After a brief discussion, motion by President Rojas, seconded by Director Hernandez, to cancel the December 24, 2018 Regular Board of Director's Meeting and to schedule a Special Board of Director's Meeting for Tuesday, December 18, 2018 at 5:30 pm.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

- B.** Consideration to Lease 500 Acre-Feet of Main San Gabriel Groundwater Production Rights to the Industry Public Utilities Commission.

- Mr. Galindo summarized his staff report and groundwater rights lease analysis that was provided in the meeting agenda packet.
- He explained that the groundwater productions rights that are proposed to be leased are in excess of the District's needs for the production year.

After further discussion, Motion by President Rojas, seconded by Director Hastings, to authorize the General Manager to enter into an Agreement to lease 500 Acre-Feet of 2018-19 Main San Gabriel Basin Groundwater Production Rights to the Industry Public Utilities Commission for \$379,470.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

- C.** Consideration to Lease 250 Acre-Feet of Groundwater Production Rights to San Gabriel County Water District.

After discussion, motion by Vice President Escalera, seconded by Director Hernandez, to authorize the General Manager to enter into an Agreement to lease 250 Acre-Feet of 2018-19 Main San Gabriel Basin Groundwater Production Rights to San Gabriel County Water District for \$189,735.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

- D.** Consideration of Resolution No. 257, Honoring Director Charles "Charlie" Aguirre for his Seventeen Years of Service on the Board of Directors.

After a brief discussion, motion by President Rojas, seconded by Director Hernandez, to approve Resolution No. 257.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

E. Consideration of Resolution No. 258, Honoring Rosa B. Ruehlman for her Retirement from the District.

After a brief discussion, motion by President Rojas, seconded by Director Hastings, to approve Resolution No. 258.

Motion was approved by the following vote:

Ayes: Rojas, Escalera, Barajas, Hastings and Hernandez.

Nays: None.

Workshop on the 2019 District Budget

- Mr. Galindo provided a presentation (enclosed) on the draft proposed District budget for the 2019 calendar year.
- Mr. Galindo reviewed the projected revenue and expenses for the end of the current year and then reviewed staff's proposed budget for the coming year.
- He added that there is no action to be taken at this time and said that at the December 18, 2018, special meeting of the Board; he will be presenting the draft budget document for their review and approval.
- There was much discussion on various items in the proposed budget, but no action was taken.

General Manager's Report:

- Mr. Galindo congratulated Vice President Escalera, Director Hernandez and congratulated and welcomed Director Barajas.

Information Items:

A. Upcoming Events.

- Mrs. Herrera provided an update on upcoming events and verified with the Directors who will be planning on attending the next few events.
- She gave the Board information on the upcoming Christmas party.

B. Correspondence to the Board of Directors.

- Included in the Board Meeting Agenda Packet.

Board Member Comments:

A. Report on events attended.

- President Rojas attended 1 event; ACWA JPIA 2018 Fall Conference.
- Director Hernandez attended 1 event; ACWA 2018 Fall Conference.

B. Other comments.

- Board Members congratulated and welcomed newly appointed Director Cesar Barajas and new District Counsel Jim Ciampa to the District.

Attorney Comments:

Mr. Ciampa thanked the Board and Staff and stated he is looking forward to serving the District as General Counsel.

Future Agenda Items:

No Future Agenda Items.

Adjournment:

With no further business or comment, the meeting was adjourned at 6:49 p.m.

William R. Rojas, President

Greg B. Galindo, Secretary

Association of Ground Water Agencies - American Ground Water Trust

AGWA – AGWT Annual Conference

“Everything aquifers and groundwater management”



Monday, February 11 and Tuesday, February 12, 2019
Gateway Hotel, 2200 East Holt Boulevard, Ontario, California 91761



See website for field visit opportunity to Regional Recycled Water Program (transportation not provided)

Background

The first AGWA/AGWT joint conference was held in Ontario, CA in 2000. Since then, this annual event has provided an important information exchange and networking opportunity for California’s water agencies, utilities and water districts, and for all water professionals (scientific, engineering, managerial, legal, environmental, regulatory), end-users of water, and local and state elected officials involved with water policy issues. The focus of every program is on current groundwater management issues in California.

Continuing Education

Anticipated approval for CA Drinking Water Operators – 11 Contact Hours

2019 Conference Sponsors – sign-up now to join them!



**Regional Recycled Water
Advanced Purification Center**

POST-CONFERENCE TOUR

Wednesday, Feb. 13th - Sign-up: www.agwt.org/events

9:30 am -11:30 am
**Joint Water Pollution Control Plant,
24501 S. Figueroa Street, Carson, 90745**

Learn about the Advanced Purification Center. A new demonstration facility that tests an innovative process to purify wastewater for groundwater replenishment. It could lead to a full-scale program that purifies 150 million gpd and replenishes four groundwater basins in Southern California, making it one of the largest of its kind in the world. The program is a partnership of The Metropolitan Water District of Southern California and the Sanitation Districts of Los Angeles County.

Monday February 11, 2019

7:30 – 8:30	REGISTRATION (Coffee & pastries – network with exhibitors)
8:30 – 8:40	OPENING REMARKS FROM AGWA AND AGWT Anthony Zampielo, Chairman, Association of Ground Water Agencies Andrew Stone, Executive Director, American Ground Water Trust
8:40 – 9:10	KICK-OFF PRESENTATION METROPOLITAN WATER DISTRICT: UPDATE ON SOUTHERN CALIFORNIA REGIONAL GROUNDWATER CONDITIONS Matthew D. Hacker, Senior Resource Specialist, Metropolitan Water District, Los Angeles, CA
9:10 – 9:40	THE ELUSIVE SUSTAINABILITY OBJECTIVE GROUNDWATER SUSTAINABILITY PLANNING: GROUNDWATER MODELING TO EVALUATE GROUNDWATER/SURFACE WATER INTERACTIONS AND CLIMATE CHANGE IMPACTS Abhishek Singh, PhD, PE, Manager - California Operations, Senior Water Resources Engineer, INTERA Inc. Torrance, CA and Bryan Bondy, PG, CHG, Bondy Groundwater Consulting, Inc., (co-author recognition - David Jordan, PE, INTERA Inc.)
9:40 – 10:10	INVITED KEYNOTE PRESENTATION

NEW FUNDING FOR STORMWATER CAPTURE

Mark Pestrella, Director, LA County Public Works, Los Angeles, CA (invited)

10:10 10:30 BREAK

11:30 – 12:00

Session 1

IDENTIFYING, QUANTIFYING AND DEALING WITH CONTAMINANTS OF EMERGING CONCERN (CECs)

(Including 1,2,3-TCP, hexavalent chromium, PPCPs, PFAS, perchlorate, 1-4,dioxane, NDMA and others!) Water agencies are faced with an urgent need to respond to concerns about health issues, property values, remediation options and infrastructure costs related to the identification, measurement and treatment of these compounds.

Moderator: Rick Zimmer, Senior Account Manager, Eurofins Eaton Analytical, LLC, Monrovia, CA

CECs IN THE LOS ANGELES (CENTRAL/WEST) BASIN

Brian Partington, Senior Hydrologist, Water Replenishment District of Southern California, Lakewood, CA

CECs IN THE ORANGE COUNTY GROUNDWATER BASIN

Patrick Versluis, Director of Water Quality, Orange County Water District, Fountain Valley, CA Presenter,

CECs IN THE SAN GABRIEL BASIN

Randy Schoellerman, Assistant Executive Director, San Gabriel Basin Water Quality Authority, West Covina, CA

CECs IN THE CHINO BASIN

Presenter to be determined

12:00 – 1:00

LUNCH (provided)

1:00 – 2:20 -

Session 2

PASO ROBLES BASIN - FIRST JURY TRIAL OVER GROUNDWATER RIGHTS IN CALIFORNIA

A Santa Clara County Superior Court jury found on Sept. 24, 2018 that a group of public water suppliers in San Luis Obispo County had the right to pump groundwater from a large groundwater basin in San Luis Obispo and Monterey Counties. The four-week trial pitted agricultural interests against public water suppliers during a time of extreme water tension due to drought and drought-like conditions in the State. What comes next?

Anthony Brown, CEO & Principal Hydrologist, Aquilogic, Costa Mesa, CA

Jeffrey V. Dunn, JD, Attorney, Partner, Best Best Krieger Law, Irvine, CA

2:20 – 3:50

Session 3

THE CLOUD & WATER RESOURCES MANAGEMENT

Moderator to be announced

In the natural hydrologic system, water moves from the meteorological clouds to aquifers. In the modern management of groundwater, the movement of hydrogeological data is from the ground to the cyberspace cloud. Management is the key to groundwater sustainability. Does the "cyberspace cloud" help?

NEXT GENERATION GROUNDWATER LEVEL INFORMATION SYSTEMS: EXTENDING WELL DATA NETWORKS BEYOND THE WELLFIELD TO INFORM OPERATION AND MANAGEMENT DECISIONS

Chuck Dunning, PhD, PG, Vice President Business Development, WellIntel, Milwaukee, WI

HELPING GSAS ACHIEVE SUSTAINABILITY USING FOCUSED GROUNDWATER MANAGEMENT SOFTWARE

Aaron Collier, PG, Vice President, Collier Consulting, Stephenville, TX

DEVELOPING A COMPREHENSIVE DATA MANAGEMENT SYSTEM FOR INDIAN WELLS VALLEY - PAINFUL BUT NECESSARY

Tim Parker, PG, CEG, CHG, President, Parker Groundwater, Sacramento, CA

3:50 – 4:00

BREAK

4:00 – 5:30

Session 4

DOWN-HOLE TECHNOLOGY FOR EFFICIENT GROUNDWATER PUMPING, RECHARGE AND WATER QUALITY CONTROL

Water engineers, consultants and agency managers can benefit from technology updates about what happens down a well. Water wells are engineered holes in the ground. The equipment that is selected for pumping, recharge and for refining well design can have significant economic impacts on construction and operation costs. Drawing up specifications for wells is best done with an understanding of equipment options and awareness of how advance information of subsurface geochemistry can inform pumping and treatment decisions.

Moderator: Andrew Stone, Executive Director, American Ground Water Trust, Concord, NH

RAPID HIGH RESOLUTION ZONAL AQUIFER GEOCHEMISTRY AND FLOW DOWN TO 3000 FEET

Noah Heller, President, Best Environmental Subsurface Science and Technologies, San Rafael, CA,

THE DESIGN AND OPERATION OF DOWNHOLE VALVE EQUIPMENT FOR EFFICIENT OPERATION IN AQUIFER STORAGE RECOVERY WELLS

Kent Madison, President, 3RValve LLC, Echo, OR

THE WELL PUMP IS THE HEART OF GROUNDWATER SYSTEMS: HOW TO SELECT THE RIGHT PUMP AND SIMPLE ROUTINE DIAGNOSTICS TO KEEP YOUR PUMP HEALTHY

David Kill, PE, Training Consultant, Xylem Goulds Water Technology, St. Paul, MN

5:30 – 7:00

RECEPTION (Cash bar)

Tuesday February 12, 2019

7:30 – 8:30

REGISTRATION

8:30 – 10:00

Session 5

CHALLENGES TO ENSURING SAFE SUSTAINABLE GROUNDWATER SUPPLY IN RURAL AREAS OF CALIFORNIA

Water Supply responsibilities in California extend beyond providing for the needs of the major irrigation industries and the water agencies with large service populations. The more rural areas of the state also have sustainability and water quality issues. As more people are choosing to live in the foothills and in areas away from major urban centers and the reach of pipelines, there needs to be a closer focus on how groundwater professionals can help maintain affordable and safe water supply for small systems and homeowners.

Moderator to be announced

PFAS: WIDE-RANGING SOURCES AND IMPACTS TO CALIFORNIA WATER SUPPLIES

Gregory Schnaar, PhD, Principal Environmental Scientist, Daniel B. Stephens & Associates, Washington, DC

GROUNDWATER MANAGEMENT IN FRACTURED ROCK AQUIFERS SERVING RURAL NEIGHBORHOODS, VINEYARDS, FARMS AND RANCHES

Stephen J. Baker, PG, HG, Hydrogeologist, Living Water® programming, Nevada City, CA

SOLVING WATER SUPPLY CHALLENGES FOR CALIFORNIA'S SMALLER COMMUNITIES

Dan Demoss, Executive Director, California Rural Water Association, Sacramento, CA.

10:00 - 10:30

INVITED PRESENTATION FROM CALIFORNIA'S GROUNDWATER INFORMATION GURU

WHERE AND HOW TO GET INFORMATION: CALIFORNIA WATER LIBRARY AND THE GROUNDWATER EXCHANGE

Chris Austin, *Maven's Notebook*, The Groundwater Exchange, *California Water Library*, Santa Clarita, CA

10:30 – 10:50

BREAK

10:50 – 12:20

Session 6

WATER AGENCY/WATER DISTRICT: COMMUNICATION, OUTREACH AND EDUCATION INITIATIVES

WHY THEY ARE NEEDED AND HOW SUCCESS IS MEASURED

Why do water agencies invest in education programs? What are the benefits from having the customer base understand where their water comes from and how it is delivered? How do agency educators decide on their targets? Is "outreach" different from "education" and is there a dividing line between public relation programs and education? What initiatives are shown to be effective and how can their effectiveness be assessed?

Moderator: Andrew Stone, Executive Director, American Ground Water Trust, Concord, NH

Gina Ayala, Principal Communications Specialist, Orange County Water District, Fountain Valley, CA

Rachel McGuire Communications Manager, Western Municipal Water District, Riverside, CA

Adrian Hightower, Education Unit Manager, Metropolitan Water District, Los Angeles, CA

12:20 – 1:20

LUNCH

1:20 – 2:50

Session 7

GEOPHYSICS AT THE FRESH WATER/SALT WATER INTERFACE OF SOUTHERN CALIFORNIA'S COASTAL AQUIFERS

Coastal groundwater conditions in Southern California range from freshwater discharge off-shore, uncontrolled salt water intrusion through multilayered and faulted aquifer systems, and relic intrusion plumes trapped behind fresh water barrier well systems. Data from electrical resistivity and time domain electromagnetic induction from airborne geophysical investigations can provide valuable information for characterizing and modeling saline/freshwater dynamics at coastal and inland sites.

Moderator – John Jansen, Senior Geophysicist/Hydrogeologist, Collier Consulting, West Bend, WI

GROUNDWATER DISCHARGE & SALT WATER INTRUSION ALONG THE SOUTHERN CALIFORNIA COAST

John Jansen, PhD, PG, PGp, Senior Geophysicist/Hydrogeologist, Collier Consulting, West Bend, WI

AIRBORNE GEOPHYSICAL INVESTIGATIONS OF SALT WATER INTRUSION ALONG COASTAL CALIFORNIA

Theodore Asch, PhD, PGp, Research Geophysicist, Aqua Geo Frameworks, LLC, Lakewood, CO

SALT WATER & FRESH WATER INTERACTION AND AIRBORNE ELECTROMAGNETIC SURVEYING

Max Halkjaer, Hydrogeologist, Geophysicist, Ramboll Group, København S Denmark

2:50 – 3:00

BREAK

3:00 – 4:30

Session 8

SGMA FEE ISSUES:

HOW TO FUND GSA IMPLEMENTATION, GSP PROJECTS ETC. HOW TO AVOID PROP 218 PITFALLS

As GSAs push to meet the upcoming GSP deadline, it is critical not to overlook funding practices. How will your GSA employ its fee authority to fund the GSA and GSP? What are other GSAs doing to guarantee funding is available for GSP implementation? This panel dives into the nuts and bolts of fee setting to ensure your GSA secures both sustainable funding and sustainable groundwater management.

Moderator and panelist:

Jena Acos, JD, Attorney, Brownstein Hyatt Farber Schreck, Santa Barbara, CA

Mack Carlson, JD, Attorney, Brownstein Hyatt Farber Schreck, Santa Barbara, CA

Mark Hildebrand, Principal, Hildebrand Consulting, Oakland, CA

4:30

WRAP-UP, Continuing education sign-out and ADJOURN

REGISTRATION FORM

AGWA/AGWT ANNUAL GROUNDWATER CONFERENCE

Monday and Tuesday, February 11 & 12, 2019

Complete information below and fax to 603 228-6557 or register on-line at www.agwt.org/events		
Early bird payment must be received BEFORE Dec 31, 2018	Two Day Feb 11 AND 12	One Day Feb 11 OR Feb 12
YOU MUST CHECK ONE:→	<input type="checkbox"/>	<input type="checkbox"/> or <input type="checkbox"/>
General Registration BEFORE Dec 31, 2018	<input type="checkbox"/> \$400	<input type="checkbox"/> \$245
AGWT Member BEFORE Dec 31, 2018	<input type="checkbox"/> \$375	<input type="checkbox"/> \$220
General Registration AFTER Dec 31	<input type="checkbox"/> \$440	<input type="checkbox"/> \$245
AGWT Member AFTER Dec 31	<input type="checkbox"/> \$415	<input type="checkbox"/> \$220
Full-Time Student* (ID required at Registration)	<input type="checkbox"/> \$120	<input type="checkbox"/> \$80
Download of presentation ppts (Registrant Price)	<input type="checkbox"/> \$30	
Exhibit Table (personal registration also required)	<input type="checkbox"/> \$300	
Field trip (Feb 13) (Conf registration required; transportation not provided)	<input type="checkbox"/> \$50	
<small>*Registration Includes: access to exhibits, reception, breaks and lunch(s)</small>		
Total for all checked boxes \$		
To be an event sponsor, call AGWT at 800 423-7748 or visit our website, www.agwt.org/events, for more information		

SPEAKER REGISTRATION ONLY:

Speakers receive complimentary registration for the day of their presentation

Speaker Presentation Date Feb 11 Feb 12
 Attending (day not presenting) Feb 11 - \$100 Feb 12 - \$100

Payment Information:

CHECK [payable to: AGWT] AMEX/VISA/MC/Discover PO # _____

AMOUNT AUTHORIZED \$ _____

Name on Card _____
 Card No. _____ Expiration Date _____
 Cardholder Email _____
 Company Name _____
 Attendee Name _____
 Attendee Email _____
 Position/Job Title _____
 Address _____
 City _____ State _____ Zip _____
 Phone _____

REGISTER ONLINE:
agwt.org/events

MAIL TO:
 American Ground Water Trust
 50 Pleasant Street, Suite 2
 Concord, NH 03301-4073

FAX: (603) 228-6557

TEL: (603) 228-5444

? QUESTIONS:
 (800) 423-7748
 9:00-4:00pm (Eastern Time)



Summary of Cash and Investments November 2018

La Puente Valley County Water District

Investments	Interest Rate (Apportionment Rate)	Beginning Balance	Receipts/ Change in Value	Disbursements/ Change in Value	Ending Balance
Local Agency Investment Fund	2.16%	\$ 2,694,382.10	\$ -	\$ -	\$ 2,694,382.10
Raymond James Financial Services		\$ 355,564.54	\$ 433.32		\$ 355,997.86
Checking Account					
Well Fargo Checking Account (per General Ledger)		\$ 331,211.51	\$ 507,260.50	\$ 424,123.24	\$ 414,348.77
District's Total Cash and Investments:					\$ <u>3,464,728.73</u>

Industry Public Utilities

Checking Account	Beginning Balance	Receipts	Disbursements	Ending Balance
Well Fargo Checking Account (per General Ledger)	\$ 1,006,430.32	\$ 183,317.09	\$ 122,173.16	\$ 1,067,574.25
IPU's Total Cash and Investments:				\$ <u>1,067,574.25</u>

I certify that; (1) all investment actions executed since the last report have been made in full compliance with the Investment Policy as set forth in Resolution No. 237 and, (2) the District will meet its expenditure obligations for the next six (6) months.

, General Manager

Date: 12.14.18

Greg B. Galindo

La Puente Valley County Water District (Treatment Plant Included)
Statement of Revenues and Expenses
For the Period Ending November 30, 2018
(Unaudited)

<u>DESCRIPTION</u>	COMBINED YTD 2018	COMBINED BUDGET 2018	92% OF BUDGET	COMBINED 2017 YE
Total Operational Rate Revenues	\$ 1,821,274	\$ 2,031,000	90%	\$ 1,981,901
Total Operational Non-Rate Revenues	2,112,451	2,733,100	77%	\$ 260,272
Total Non-Operating Revenues	198,967	291,100	68%	2,110,238
TOTAL REVENUES	4,132,691	5,055,200	82%	4,092,139
Total Salaries & Benefits	1,803,359	1,959,600	92%	1,287,342
Total Supply & Treatment	1,537,686	1,714,200	90%	1,486,941
Total Other Operating Expenses	316,594	460,100	69%	274,747
Total General & Administrative	319,924	500,500	64%	347,296
TOTAL EXPENSES	3,977,562	4,634,400	86%	3,396,326
TOTAL OPERATIONAL INCOME	155,130	420,800	37%	695,813
Total Capital Improvements	(219,023)	(1,235,000)	18%	(82,810)
Total Capital Outlay	(28,286)	(50,000)	57%	(39,731)
TOTAL CAPITAL	(247,308)	(1,285,000)	19%	(122,542)
INCOME (AFTER CAPITAL EXPENSES)	(92,179)	(864,200)	11%	573,272
Grant Proceeds	-	300,000	0%	-
Loan Proceeds	-	500,000	0%	-
Loan Repayment	-	-	0%	-
PROJECTED CHANGE IN CASH	(92,179)	(64,200)	144%	573,272
Non-Cash Items (Dep. & OPEB)	(266,025)	725,000	-37%	(474,668)
NET INCOME (LOSS)	\$ (358,204)	\$ 660,800	-54%	\$ 98,603

La Puente Valley County Water District
Statement of Revenues and Expenses
For the Period Ending November 30, 2018
(Unaudited)

Description	November 2018	YTD 2018	ANNUAL BUDGET 2018	92% OF BUDGET	YEAR END 2017
Operational Rate Revenues					
Water Sales	\$ 76,825	\$ 1,155,055	\$ 1,295,000	89%	\$ 1,251,382
Service Charges	46,683	547,621	608,500	90%	604,424
Surplus Sales	3,975	40,120	38,000	106%	35,769
Customer Charges	3,069	28,379	33,300	85%	33,425
Fire Service	1,330	48,374	55,500	87%	56,096
Miscellaneous Income	-	1,725	700	246%	805
Total Operational Rate Revenues	131,882	1,821,274	2,031,000	90%	1,981,901
Non-Rate Operational Revenues					
Management Fees	-	214,284	261,700	82%	194,810
Other O & M Fees	-	-	13,000	0%	65,461
PVOU Service Fees (Labor)	-	12,090	42,900	28%	-
BPOU Service Fees (Labor)	23,412	284,965	278,800	102%	-
IPU Service Fees (Labor)	56,993	633,101	715,800	88%	-
Total Non Rate Operational Revenues	80,405	1,144,439	1,312,200	87%	260,272
Non Operating Revenues					
Taxes & Assessments	6,321	128,022	215,000	60%	230,516
Rental Revenue	3,025	33,013	36,100	91%	34,988
Interest Revenue	-	13,768	17,000	81%	27,436
Miscellaneous Income	286	24,165	18,000	134%	76,053
Contributed Capital	-	-	-	N/A	210,130
Developer Fees	-	-	5,000	0%	81,095
Total Non-Operational Revenues	9,632	198,967	291,100	68%	920,490
TOTAL REVENUES	221,918	3,164,680	3,634,300	87%	2,902,391
Salaries & Benefits					
Total District Wide Labor	102,118	1,071,680	1,142,700	94%	497,621
Directors Fees & Benefits	10,393	109,281	117,300	93%	117,385
Benefits	26,189	281,473	303,100	93%	124,987
OPEB Payments	2,094	116,717	150,000	78%	157,030
Payroll Taxes	7,264	85,417	90,600	94%	43,150
Retirement Program Expense	11,746	138,791	155,900	89%	64,566
Total Salaries & Benefits	159,802	1,803,359	1,959,600	92%	1,004,737
Analysis Purposes Only:					
<i>Offsetting Revenue</i>	(80,405)	(930,156)	(1,057,500)	88%	-
<i>District Labor Net Total</i>	79,397	873,203	902,100	97%	-
Supply & Treatment					
Purchased & Leased Water	-	376,920	379,500	99%	421,870
Power	11,994	141,911	157,000	90%	152,220
Assessments	-	157,211	221,900	71%	132,114
Treatment	208	2,804	6,700	42%	4,079
Well & Pump Maintenance	-	18,929	32,000	59%	11,841
Total Supply & Treatment	12,203	697,775	797,100	88%	722,124
Other Operating Expenses					
General Plant	923	23,883	42,300	56%	29,918
Transmission & Distribution	802	80,595	90,500	89%	50,636
Vehicles & Equipment	4,362	24,948	30,300	82%	14,669
Field Support & Other Expenses	1,439	42,088	68,500	61%	30,329
Regulatory Compliance	1,124	33,428	51,500	65%	28,754
Total Other Operating Expenses	8,650	204,941	283,100	72%	154,307

La Puente Valley County Water District
Statement of Revenues and Expenses
For the Period Ending November 30, 2018
(Unaudited)

Description	November 2018	YTD 2018	ANNUAL BUDGET 2018	92% OF BUDGET	YEAR END 2017
General & Administrative					
District Office Expenses	1,399	28,366	61,800	46%	37,453
Customer Accounts	1,173	17,015	20,400	83%	20,907
Insurance	-	40,755	69,900	58%	60,490
Professional Services	-	119,613	160,000	75%	132,598
Training & Certification	303	36,671	37,700	97%	29,068
Public Outreach & Conservation	54	30,803	32,500	95%	15,717
Other Administrative Expenses	553	30,252	70,200	43%	29,176
Total General & Administrative	3,483	303,476	452,500	67%	325,409
TOTAL EXPENSES	184,137	3,009,550	3,492,300	86%	2,206,578
TOTAL OPERATIONAL INCOME	37,781	155,130	142,000	109%	695,813
Capital Improvements					
Fire Hydrant Repair/Replacements	-	(10,908)	-	N/A	(178)
Zone 3 Improvements	(18,013)	(173,679)	(220,000)	79%	(7,022)
Service Line Replacements	-	(21,199)	(20,000)	106%	(33,456)
Valve Replacements	-	(7,096)	(10,000)	71%	(13)
Main & 1st Street Building Retrofit	-	(4,080)	(35,000)	12%	-
Phase 1 - Recycled Water System	-	(1,879)	(900,000)	0%	-
SCADA Improvements	-	-	(15,000)	0%	-
Meter Read Collection System	-	(181)	(35,000)	1%	(42,141)
Total Capital Improvements	(18,013)	(219,023)	(1,235,000)	18%	(82,810)
Capital Outlay					
Communications Systems Upgrade	-	-	-	N/A	-
Backhoe	-	-	-	N/A	-
Truck(s)	-	(28,286)	(40,000)	71%	(39,731)
Other Equipment	-	-	(10,000)	0%	-
Total Capital Outlay	-	(28,286)	(50,000)	57%	(39,731)
TOTAL CAPITAL	(18,013)	(247,308)	(1,285,000)	19%	(122,542)
INCOME (AFTER CAPITAL EXPENSES)	19,768	(92,179)	(1,143,000)	8%	573,272
Loan & Debt Repayment					
Recycled Water System (Grant Revenues)	-	-	300,000	0%	-
Recycled Water System (Loan Proceeds)	-	-	500,000	0%	-
CASH DIFFERENCE	19,768	(92,179)	(343,000)	27%	573,272
Add Back Capitalized Assets	18,013	247,308	1,285,000	19%	122,542
Less Depreciation Expense	(31,666.67)	(348,333.33)	(380,000)	92%	(360,602)
Less OPEB Expense - Not Funded	-	-	-	N/A	(71,263)

Treatment Plant
Statement of Revenues and Expenses
For the Period Ending November 30, 2018
(Unaudited)

Description	November 2018	YTD 2018	ANNUAL BUDGET 2018	92% OF BUDGET	YEAR END 2017
Non-Rate Operational Revenues					
Reimbursements from CR's	134,206	968,011	\$ 1,420,900	68%	\$ 1,189,748
Miscellaneous Income	-	-	-	N/A	-
Total Non-Rate Operational Revenues	134,206	968,011	1,420,900	68%	1,189,748
Salaries & Benefits					
<i>BPOU TP Labor (1)</i>	23,412	284,965	278,800	102%	282,605
Contract Labor	-	-	-	N/A	-
Total Salaries & Benefits	23,412	284,965	278,800	102%	282,605
Supply & Treatment					
NDMA, 1,4-Dioxane Treatment	5,975	206,844	170,000	122%	195,826.73
VOC Treatment	-	1,756	17,800	10%	25,373.87
Perchlorate Treatment	91,294	418,205	415,000	101%	315,421.42
Other Chemicals	1,378	14,148	16,600	85%	17,829
Treatment Plant Power	12,658	171,539	202,700	85%	174,702.82
Treatment Plant Maintenance	682	18,460	75,000	25%	19,347.14
Well & Pump Maintenance	-	8,959	20,000	45%	16,314.93
Total Supply & Treatment	111,988	839,911	917,100	92%	764,816
Other Operating Expenses					
General Plant	984	14,714	45,000	33%	12,311.60
Transmission & Distribution	-	198	-	N/A	1,320.76
Vehicles & Equipment	877	10,240	10,000	102%	10,412.75
Field Support & Other Expenses	-	55	15,000	0%	-
Regulatory Compliance	21,857	86,446	107,000	81%	96,395.21
Total Other Operating Expenses	23,717	111,653	177,000	63%	120,440
General & Administrative					
District Office Expenses	-	-	10,000	0%	-
Insurance	-	9,153	18,000	51%	9,756.84
Professional Services	-	7,296	20,000	36%	12,130.26
Total General & Administrative	-	16,448	48,000	34%	21,887
TOTAL EXPENSES	159,117	1,252,977	1,420,900	88%	1,189,748
TOTAL OPERATIONAL INCOME	(24,911)	(284,965)	-	-	-
Capital Outlay					
Scada Computer	-	-	-	N/A	-
Total Capital Outlay	-	-	-	N/A	-
Depreciation Expense	(15,000)	(165,000)	(180,000)	92%	(165,346)
Total Non-Cash Items (Dep. & OPEB)	(15,000)	(165,000)	(180,000)	92%	(165,346)
NET INCOME (LOSS)	\$ (39,911)	\$ (449,965)	\$ (180,000)	250%	\$ (165,346)

INDUSTRY PUBLIC UTILITIES - WATER OPERATIONS
Statement of Revenue and Expenses Summary
For the Period Ending November 30, 2018
(Unaudited)

DESCRIPTION	November 2018	FISCAL YTD 2018-2019	BUDGET FY 2018-2019	42% OF BUDGET	FY END 2017-2018
Total Operational Revenues	\$ 199,717	\$ 904,869	\$ 2,026,800	45%	\$ 1,920,277
Total Non-Operational Revenues	-	-	30,000	0%	40,307
TOTAL REVENUES	199,717	904,869	2,056,800	44%	1,960,584
Total Salaries & Benefits	56,993	290,015	668,600	43%	644,392
Total Supply & Treatment	3,188	71,421	848,565	8%	607,538
Total Other Operating Expenses	4,075	50,893	171,500	30%	149,475
Total General & Administrative	879	73,262	301,568	24%	245,510
Total Other & System Improvements	-	-	120,800	0%	45,748
TOTAL EXPENSES	65,135	485,590	2,111,000	23%	1,692,664
OPERATING INCOME	134,582	419,279	(54,200)	-774%	267,920
NET INCOME (LOSS)	\$ 134,582	\$ 419,279	\$ (54,200)	-774%	\$ 267,920

INDUSTRY PUBLIC UTILITIES - WATER OPERATIONS

Statement of Revenue and Expenses

For the Period Ending November 30, 2018

(Unaudited)

DESCRIPTION	November 2018	FISCAL YTD 2018-2019	BUDGET FY 2018-2019	42% OF BUDGET	FY END 2017-2018
Operational Revenues					
Water Sales	\$ 129,177	\$ 599,234	\$ 1,317,750	45.47%	\$ 1,206,751
Service Charges	55,903	251,485	600,000	41.91%	598,493
Customer Charges	1,495	7,740	21,000	36.86%	20,000
Fire Service	13,143	46,410	88,000	52.74%	95,032
Total Operational Revenues	199,717	904,869	2,026,800	44.65%	1,920,277
Non-Operational Revenues					
Contamination Reimbursement	-	-	30,000	0.00%	40,267
Developer Fees	-	-	-	N/A	-
Miscellaneous Income	-	-	-	N/A	39
Total Non-Operational Revenues	-	-	30,000	0.00%	40,307
TOTAL REVENUES	199,717	904,869	2,056,800	43.99%	1,960,584
Salaries & Benefits					
Administrative Salaries	16,129	86,045	186,800	46.06%	190,967
Field Salaries	20,360	99,409	238,000	41.77%	219,465
Employee Benefits	12,756	63,590	149,000	42.68%	143,834
Pension Plan	5,159	26,184	57,440	45.59%	54,946
Payroll Taxes	2,590	13,188	30,360	43.44%	29,215
Workman's Compensation	-	1,598	7,000	22.83%	5,964
Total Salaries & Benefits	56,993	290,015	668,600	43.38%	644,392
Supply & Treatment					
Purchased Water - Leased	-	-	377,614	0.00%	326,781
Purchased Water - Other	1,766	8,460	17,500	48.34%	17,128
Power	1,423	51,425	120,000	42.85%	119,441
Assessments	-	11,030	184,752	5.97%	135,945
Treatment	-	-	6,200	0.00%	4,834
Well & Pump Maintenance	-	506	142,500	0.35%	3,409
Total Supply & Treatment	3,188	71,421	848,565	8.42%	607,538
Other Operating Expenses					
General Plant	149	2,615	10,500	24.90%	4,932
Transmission & Distribution	582	30,907	64,000	48.29%	54,395
Vehicles & Equipment	-	-	32,000	0.00%	31,553
Field Support & Other Expenses	1,174	10,869	35,000	31.05%	31,104
Regulatory Compliance	2,169	6,502	30,000	21.67%	27,491
Total Other Operating Expenses	4,075	50,893	171,500	29.68%	149,475

INDUSTRY PUBLIC UTILITIES - WATER OPERATIONS

Statement of Revenue and Expenses

For the Period Ending November 30, 2018

(Unaudited)

DESCRIPTION	November 2018	FISCAL YTD 2018-2019	BUDGET FY 2018-2019	42% OF BUDGET	FY END 2017-2018
General & Administrative					
Management Fee	-	46,428	187,568	24.75%	183,891
Office Expenses	642	4,295	21,000	20.45%	17,478
Insurance	-	11,321	15,000	75.47%	5,667
Professional Services	-	2,323	45,000	5.16%	15,576
Customer Accounts	223	5,753	16,000	35.95%	16,247
Public Outreach & Conservation	14	2,188	15,000	14.59%	3,923
Other Administrative Expenses	-	955	2,000	47.74%	2,727
Total General & Administrative	879	73,262	301,568	24.29%	245,510
Other Expenses & System Improvements (Water Operations Fund)					
Transfer to Capital or Expense	-	-	-	N/A	-
Developer Capital Contributions	-	-	-	N/A	-
Developer Project	-	-	-	N/A	-
Developer Project	-	-	-	N/A	-
Developer Project	-	-	-	N/A	-
Developer Project -	-	-	-	N/A	-
Developer Project -	-	-	-	N/A	-
Developer Project -	-	-	-	N/A	-
Net Developer Project Activity	-	-	-	-	-
Master Plan Update / Hydraulic Model	-	-	-	N/A	-
Other System Improvements (Materials)	-	-	-	N/A	-
FH Laterals	-	-	6,300	0.00%	790
Service Line Replacements	-	-	30,000	0.00%	31,693
Valve Replacements	-	-	19,500	0.00%	5,874
Plant Electrical System Improvements	-	-	-	N/A	-
Meter Installations - Industry Hills	-	-	-	0.00%	7,391
Meter Read Collection System	-	-	25,000	0.00%	-
SCADA System Assessment & Upgrades	-	-	40,000	0.00%	-
Total Other & System Improvements	-	-	120,800	0.00%	45,748
TOTAL EXPENSES	65,135	485,590	2,111,000	23.00%	1,692,664
OPERATING INCOME	134,582	419,279	(54,200)	N/A	267,920

Memo



To: Honorable Board of Directors

From: Greg B. Galindo, General Manager

Date: December 14, 2018

Re: 2019 Cost of Living Adjustment and Salary Schedule Adjustment

Summary

As customary of this District, a cost of living adjustment (COLA) of all District Employees salaries is considered each year. It is the duty of the General Manager to recommend to the Board what increase is in the best interest of the District. In past years, this recommendation has been based on the increase of the Consumer Price Index (CPI) for urban wage earners and clerical workers in our region. Although, this is the basis for the recommendation other factors are considered, such as the change in the cost for providing health benefits for District employees.

Over this past year, the annual average of the CPI for our region increased by an estimated 3.98%. For your reference, I have attached the data from the U.S. Department of Labor detailing the historical CPI for our region, for US Cities and for US Western Cities. In addition, I have included a table depicting the District's COLA calculations for the past several years.

For calendar year 2018, The Board of Directors decided to approve a 2% COLA, which was .74% less than the change in CPI. This decision was made to minimize the impact of the increasing cost for employee health benefits in 2018. In preparing my recommendation for the 2019 COLA, I analyzed the fiscal impact the adjustment to salaries will have along with the change in the cost of providing health benefits to the employees. In 2019, I project that the cost of providing health benefits for employees will increase by an average of 1.9% and the cost of providing pension benefits for employees will increase slightly as well.

Recommendation

For calendar year 2019, I recommend a 3% COLA be applied to all employee salaries and to salary ranges for each position. Enclosed is a revised District salary schedule with the proposed 3% adjustment to the ranges.

Thank you for your consideration on this matter. If you have any question, please feel free to contact me.

Enclosures:

1. Summary of CPI and Changes to COLA
2. CPI Tables for US, Western Cities & Los Angeles
3. Proposed Salary Schedule (adjusted 3%)

Summary of CPI Changes and Cost of Living Adjustments

2014 CPI Increase Calculation

	2012	2013	Point Change	Point Change / 2012	Percentage Change
CPI Annual Average	229.649	232.234	2.585	0.0113	1.13%

2015 CPI Increase Calculation

	2013	2014	Point Change	Point Change / 2013	Percentage Change
CPI Annual Average	232.234	235.273	3.039	0.0131	1.31%

2016 CPI Increase Calculation

	2014	2015	Point Change	Point Change / 2014	Percentage Change
CPI Annual Average	235.273	236.646	1.373	0.0058	0.58%

2017 CPI Increase Calculation

	2015	2016	Point Change	Point Change / 2015	Percentage Change
CPI Annual Average	236.646	240.140	3.494	0.0148	1.48%

2018 CPI Increase Calculation

	2016	2017	Point Change	Point Change / 2016	Percentage Change
CPI Annual Average	240.140	246.722	6.582	0.0274	2.74%

2019 CPI Increase Calculation

	2017	2018	Point Change	Point Change / 2017	Percentage Change
CPI Annual Average	244.899	254.620	9.721	0.0397	3.97%

Based on US Department of Labor -Bureau of Labor and Statistics' Consumer Price Index- Urban Wage Earners and Clerical Workers (Los Angeles, Riverside and Orange Counties)

2014 Approved COLA	2015 Approved COLA	2016 Approved COLA	2017 Approved COLA	2018 Approved COLA	2019 Recommended COLA
1.00%	1.35%	1.00%	0.00%	2.00%	3.00%
-0.13%	0.04%	0.42%	-1.48%	-0.74%	-0.98%
Adjusted downward to cover increase in benefits	Board approved a 1.35 % which was .04% over the CPI Increase	Board approved a 1% which was .42% over the CPI Increase	Adjusted downward to cover increase in benefits	Adjusted downward slightly to cover increase in benefits	

CPI-Urban Wage Earners and Clerical Workers (Current Original Data Value)

Series Id: CWUR0000SA0

Not Seasonally Adjusted

Series: All items in U.S. city average, urban wage earners and

Area: U.S. city average

Item: All items

Base: 1982-84=100

Years: 2008 to 2018

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	HALF1	HALF2	% Change
2008	206.744	207.254	209.147	210.698	212.788	215.223	216.304	215.247	214.935	212.182	207.296	204.813	210.309	211.796	
2009	205.700	206.708	207.218	207.925	208.774	210.972	210.526	211.156	211.322	211.549	212.003	211.703	207.883	211.377	3.36%
2010	212.568	212.544	213.525	213.958	214.124	213.839	213.898	214.205	214.306	214.623	214.750	215.262	213.426	214.507	1.68%
2011	216.400	217.535	220.024	221.743	222.954	222.522	222.686	223.326	223.688	223.043	222.813	222.166	220.196	222.954	3.21%
2012	223.216	224.317	226.304	227.012	226.600	226.036	225.568	227.056	228.184	227.974	226.595	225.889	225.581	226.878	1.68%
2013	226.520	228.677	229.323	228.949	229.399	230.002	230.084	230.359	230.537	229.735	229.133	229.174	228.812	229.837	1.45%
2014	230.040	230.871	232.560	233.443	234.216	234.702	234.525	234.030	234.170	233.229	231.551	229.909	232.639	232.902	0.32%
2015	228.294	229.421	231.055	231.520	232.908	233.804	233.806	233.366	232.661	232.373	231.721	230.791	231.167	232.453	0.38%
2016	231.061	230.972	232.209	233.438	234.436	235.289	234.771	234.904	235.495	235.732	235.215	235.390	232.901	235.251	1.99%
2017	236.854	237.477	237.656	238.432	238.609	238.813	238.617	239.448	240.939	240.573	240.666	240.526	237.974	240.128	2.18%
2018	241.919	242.988	243.463	244.607	245.770	246.196	246.155	246.336	246.565	247.038	246.551	247.260	244.157	246.473	2.80%

Estimated

CPI-Urban Wage Earners and Clerical Workers (Current S
Original Data Value

Series Id: CWUR0400SA0

Not Seasonally Adjusted

Series All items in West urban, urban wage earners and clerical

Area: West

Item: All items

Base 1982-84=100

Years: 2008 to 2018

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual	HALF1	HALF2	% Change
2008	210.342	210.816	213.159	214.355	216.029	218.508	219.248	217.854	217.028	215.499	210.870	208.088	214.316	213.868	214.765	
2009	209.367	210.492	210.661	211.386	212.263	213.973	213.541	213.988	214.490	214.718	214.228	213.919	212.752	211.357	214.147	-0.73%
2010	214.664	214.710	215.457	215.873	216.044	215.681	215.824	216.048	215.804	216.273	216.267	216.847	215.791	215.405	216.177	1.43%
2011	217.995	219.368	221.830	223.268	223.944	223.237	222.815	223.204	224.237	224.268	223.785	222.968	222.577	221.607	223.546	3.14%
2012	223.849	224.956	227.271	227.686	228.189	227.543	226.460	227.681	228.798	229.849	227.767	226.585	227.220	226.582	227.857	2.09%
2013	227.197	229.319	230.226	230.056	230.555	230.723	230.882	231.084	231.553	231.244	230.390	230.356	230.299	229.679	230.918	1.36%
2014	230.937	231.785	233.375	234.081	235.579	235.845	236.051	235.820	235.974	235.343	233.499	232.108	234.200	233.600	234.799	1.69%
2015	230.843	232.364	234.802	235.222	237.509	237.441	238.151	237.791	236.999	236.728	236.003	235.728	235.798	234.697	236.900	0.68%
2016	236.888	236.747	237.415	238.757	239.973	240.365	240.395	240.291	241.052	241.744	241.167	241.098	239.658	238.358	240.958	1.64%
2017	242.384	243.810	244.489	245.454	246.096	246.155	246.373	246.978	248.379	248.883	248.863	249.055	246.410	244.731	248.089	2.82%
2018	250.416	251.704	252.644	253.933	255.316	255.804	255.931	256.311	256.950	258.149	256.978	256.369	255.042	253.303	256.781	3.50%

Estimated

CPI-Urban Wage Earners and Clerical Workers (Current Original Data Value)

Series Id: CWURS49ASA0

Not Seasonally Adjusted

Series: All items in Los Angeles-Long Beach-Anaheim, CA,

Area: Los Angeles-Long Beach-Anaheim, CA

Item: All items

Base: 1982-84=100

Years: 2008 to 2018

Year	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Annual	HALF1	HALF2	% Change
2008	213.825	214.231	216.493	217.914	219.702	222.435	223.245	221.230	220.285	218.726	214.083	211.007	217.765	217.433	218.096	
2009	212.454	213.234	213.013	213.405	214.446	216.145	216.128	216.628	217.302	217.474	216.618	216.233	215.257	213.783	216.730	-1.15%
2010	217.290	217.090	218.157	218.475	218.787	218.222	218.367	218.752	218.427	219.339	218.694	219.619	218.435	218.004	218.866	1.48%
2011	221.540	222.814	225.770	227.051	226.842	225.461	224.277	224.665	226.096	226.116	225.786	224.444	225.072	224.913	225.231	3.04%
2012	226.245	227.585	230.281	230.023	230.180	228.917	228.446	230.229	231.085	233.431	230.426	228.940	229.649	228.872	230.426	2.03%
2013	230.651	232.983	233.200	232.030	232.387	232.378	232.190	232.245	232.817	232.735	231.598	231.594	232.234	232.271	232.197	1.13%
2014	232.578	233.886	235.500	235.717	236.647	236.880	236.963	236.504	236.451	235.921	233.896	232.330	235.273	235.201	235.344	1.31%
2015	231.063	232.975	235.991	235.697	238.816	237.792	239.889	238.755	237.324	237.472	237.190	236.787	236.646	235.389	237.903	0.58%
2016	238.609	238.262	239.146	239.536	240.320	240.522	240.580	240.267	240.851	241.932	240.809	240.846	240.140	239.399	240.881	1.48%
2017	242.735	244.254	244.932	245.417	246.153	245.900	246.681	247.260	248.550	249.234	249.680	249.854	246.721	244.899	248.543	2.74%
2018	251.785	253.243	254.451	255.379	256.652	256.208	256.632	257.318	258.246	259.899	258.964	258.190	256.414	254.620	258.208	3.93%

Estimated

La Puente Valley County Water District

Salary Schedule - Proposed for Calendar Year 2019

Range	Position	Time	Proposed		
			Begin	Mid	End
GM	General Manager	Annual	\$ 118,277	\$ 138,963	\$ 159,650
		Month	\$ 9,856	\$ 11,580	\$ 13,304
		Hour	\$ 56.86	\$ 66.81	\$ 76.75
ECM	Engineering & Compliance Manager	Annual	\$ 86,108	\$ 96,872	\$ 107,635
		Month	\$ 7,176	\$ 8,073	\$ 8,970
		Hour	\$ 41.40	\$ 46.57	\$ 51.75
OM	Office Manager	Annual	\$ 81,988	\$ 92,237	\$ 102,485
		Month	\$ 6,832	\$ 7,686	\$ 8,540
		Hour	\$ 39.42	\$ 44.34	\$ 49.27
WTS	Water Treatment & Supply Supervisor	Annual	\$ 81,988	\$ 92,237	\$ 102,485
		Month	\$ 6,832	\$ 7,686	\$ 8,540
		Hour	\$ 39.42	\$ 44.34	\$ 49.27
WDS	Water Distribution Supervisor	Annual	\$ 73,336	\$ 82,503	\$ 91,670
		Month	\$ 6,111	\$ 6,875	\$ 7,639
		Hour	\$ 35.26	\$ 39.66	\$ 44.07
LWT	Lead Water System Operator (Treatment)	Annual	\$ 66,744	\$ 75,087	\$ 83,430
		Month	\$ 5,562	\$ 6,257	\$ 6,953
		Hour	\$ 32.09	\$ 36.10	\$ 40.11
LWD	Lead Water System Operator (Distribution)	Annual	\$ 63,448	\$ 71,379	\$ 79,310
		Month	\$ 5,287	\$ 5,948	\$ 6,609
		Hour	\$ 30.50	\$ 34.32	\$ 38.13
WSOII	Water System Operator II	Annual	\$ 59,328	\$ 66,744	\$ 74,160
		Month	\$ 4,944	\$ 5,562	\$ 6,180
		Hour	\$ 28.52	\$ 32.09	\$ 35.65
WSOI	Water System Operator I	Annual	\$ 54,384	\$ 61,182	\$ 67,980
		Month	\$ 4,532	\$ 5,099	\$ 5,665
		Hour	\$ 26.15	\$ 29.41	\$ 32.68
WMW	Water System Maintenance Worker	Annual	\$ 48,616	\$ 54,693	\$ 60,770
		Month	\$ 4,051	\$ 4,558	\$ 5,064
		Hour	\$ 23.37	\$ 26.29	\$ 29.22
LCS	Lead Customer Support & Accounting Clerk	Annual	\$ 51,912	\$ 58,401	\$ 64,890
		Month	\$ 4,326	\$ 4,867	\$ 5,408
		Hour	\$ 24.96	\$ 28.08	\$ 31.20
CSII	Customer Support & Accounting Clerk II	Annual	\$ 46,968	\$ 52,839	\$ 58,710
		Month	\$ 3,914	\$ 4,403	\$ 4,893
		Hour	\$ 22.58	\$ 25.40	\$ 28.23
CSI	Customer Support & Accounting Clerk I	Annual	\$ 37,492	\$ 45,526	\$ 53,560
		Month	\$ 3,124	\$ 3,794	\$ 4,463
		Hour	\$ 18.03	\$ 21.89	\$ 25.75



DRAFT

ANNUAL BUDGET

Year Ending December 31, 2019

BOARD OF DIRECTORS

William R. Rojas	President
John P. Escalera	Vice President
Cesar Barajas	Director
David Hastings	Director
Henry P. Hernandez	Director

Prepared by: Greg B. Galindo, General Manager



THE LA PUENTE VALLEY COUNTY WATER
DISTRICT BOARD OF DIRECTORS AND STAFF ARE
DEDICATED TO PROVIDING OUR CUSTOMERS HIGH
QUALITY WATER, ALONG WITH COURTEOUS AND
RESPONSIVE CUSTOMER SERVICE AT THE MOST
REASONABLE COST.

Table of Contents

Sections

About La Puente Valley County Water District	4
Service Area Trends.....	5
Water Supply and Cost of Water	6
Water Quality and the Cost of Water Treatment	8
Customer Base and Water Usage.....	9
Past Water Rate Adjustments.....	9
The Budget.....	11
Direction of the District and Financial Forecast.....	11
2019 Objectives.....	15
Executive Summary	16
Water Operations Fund	16
Water Revenue - Operational.....	17
Water Revenue - Non-Operational	17
Water Expenditures.....	17
Capital Improvements and Capital Outlay.....	18

Figures

Figure 1.1 Boundary Map of District’s Service Area.....	4
Figure 1.2 Years 2014-2018 Annual Water System Demand	6
Figure 1.3 District’s Annual Production Right (2002-2018)	7
Figure 1.4 Five Year Projection of Total Cash and Reserve Fund Level.....	14

Tables


Table 1.1 Number of Connections by Category and Percentage of Demand.....	9
Table 1.2 Five Year Forecast of Revenue and Expenses.....	14
Table 1.3 2019 Capital Improvement Projects	19
Table 1.4 2019 Budget Summary	20
Table 1.5 District Budget for 2019	21
Table 1.6 District Treatment Plant Budget for 2019	23

About La Puente Valley County Water District

La Puente Valley County Water District provides safe, reliable and cost-effective drinking water to approximately 9,600 people within the communities of La Puente and the City of Industry. The District has been providing water service to these communities for over 94 years. The District was formed in August 1924 by popular vote, in accordance with the County Water District Act of 1913. In its infancy, the District consisted of approximately 1,300 acres and 200 water service connections. The area was vastly different from what it is today. At that time, most of the water produced from the District's Well Field was delivered to meet agricultural irrigation needs of the valley. Over the years, the District has grown to approximately 1,600 acres and over 2,500 water service connections. To this day, the District's Well Field continues to be the main source of supply to meet the needs of the District's customers. The boundary map of the District's service area is provided in **Figure 1.1**.



Figure 1.1 - Boundary Map of District's Service Area



A publicly elected, five-member Board of Directors governs the District. Board members serve four-year terms and elections are held every two years with terms staggered to ensure continuity. The Board is responsible for establishing District policy on a variety of issues including, but not limited to, financial planning, infrastructure investment, and water rates. Day-to-day operations are managed by the General Manager who oversees a highly-qualified staff responsible for executing ongoing operational and administrative functions. The District's employees include certified water treatment and distribution operators and an experienced administrative staff.

The District's Water System includes approximately 2,550 service connections, more than 32 miles of distribution and transmission mains, 4 wells, a state of the art groundwater treatment

facility, 5 booster pump stations, 4 pressure regulating stations and 3 reservoirs. In addition, the District manages and operates the Industry Public Utilities Water System, which includes 1,860 service connections, 34.4 miles of distribution and transmission mains, 1 active well, 5 booster pump stations, and 3 reservoirs.


Service Area Trends

Land use in the portion of the City of La Puente bounded by the District's service area is primarily residential with some commercial, public/institutional, and open space areas. Land use in the portion of the City of Industry bounded by the District's service area is primarily commercial and industrial. This portion of the District's service area is also, for the most part, fully developed. Population data for the City of Industry shows little or no growth over the next 20 years. District Staff projects that most, if not all, future developments within this portion of the District's service area will be redevelopment of commercial properties that may or may not have an impact on the water system's water demand.

Portions of the City of La Puente bounded by the District's service area are also, for the most part, fully developed. Based on the current and projected trends, the long-term population growth is projected to increase at a rate of approximately 1.0% per year. In recent years, developments within this portion of the District's service area have been infill residential type of developments. With the exception of one development in 2017, developments in the District's service area have not required major infrastructure additions and typically are accommodated by the installation of new service connections from existing water main lines, however these types of development do increase the system's water supply based on the historic water use at the developed site.

The annual amount of water used within the District's water system (water system demand) over the last 10 years (2009-2018) has averaged 1,720 acre-feet (AF). The water system demand over the past 5 years (2014-18) has been 1,566 AF. In 2018, the water system demand was approximately 9% greater than in 2017, but 2% less than compared to the 5-year average. The low water demand in 2017 was driven mainly by water conservation efforts in response to the multi-year historic State drought conditions (2012-2016). In May 2015, the District's Board of Directors adopted Resolution No. 229, which re-declared emergency water conservation restrictions and adopted the revised State Water Resources Control Board Regulations. The adopted outdoor water use restrictions yielded a substantial reduction in water system demand from 2015 through 2017. The reduction in water use has also had a significant impact on water sales revenue in 2015, 2016 and 2017. **Figure 1.2** displays the water system demand in AF for a 5-year period compared to the rolling five-year average.

Figure 1.2 - Years 2014-2018 Annual Water System Demand



Water Supply and Cost of Water


The District's primary source of supply is from three ground water wells that produce water from the adjudicated Main San Gabriel Basin (Basin). The groundwater rights in the Basin were adjudicated on the basis of mutual prescription resulting in a specific quantity in acre-feet per year for each producer. Such rights were then converted to a Pumper's Share, expressed in percent of the aggregate of all prescriptive rights. The District was adjudicated 1,097.00 acre feet of water rights based on groundwater production that occurred between calendar years 1953 and 1967. Subsequently, the District obtained the water rights of El Encanto Properties on July 22, 1974, in the amount of 33.40 acre-feet. Thus, the District's total adjudicated water rights are 1,130.40 acre-feet. This represents 0.57197 percent (Pumper's Share) of all adjudicated water rights in the Basin.

Under the Main San Gabriel Basin Judgment, the Main San Gabriel Basin Watermaster (Watermaster) annually establishes the Operating Safe Yield (OSY) for the ensuing year. This is done mainly on the basis of groundwater storage conditions as reflected by the Baldwin Park Key Well. In order to provide sufficient storage capacity in the basin to capture as much of the local stream flow as practicable, the Judgment provides that imported supplemental water will not be spread in the Basin when the Key Well elevation exceeds 250 feet above mean sea level (msl) and will be spread, insofar practicable, to maintain the elevation above 200 feet msl. Each year a producer is allowed to extract, free of Replacement Water Assessment, its share of the OSY which is established in May each year by the Watermaster. This annual share is referred to as the annual production right. Any producer can extract all the water needed for beneficial use, but the portion of such extraction, which exceeds the annual production right of the OSY, is assessed at a rate (Replacement Water Assessment), which will purchase one acre-foot of imported supplemental water for each acre-foot of excess production. Such water is then purchased by the Watermaster from the appropriate Responsible Agency (municipal water district) and used to replenish the Basin. If Basin storage is low, as indicated by the key well elevation, the OSY is set at a lower level so that more Replacement Water may be purchased to increase Basin storage. If Basin storage is relatively high, the OSY is increased so that

Replacement Water will not increase Basin storage to the point that local water runoff will be un-storable.

The Main San Gabriel Basin watershed continues to be in the state of a drought. The lack of precipitation locally has resulted in a major decrease in groundwater replenishment. After recovering to normal water levels in 2011, water levels at the District's well field have declined significantly over the last seven years. Although there has been a major decline in water levels, the District remains fortunate that its well field is located very near the middle of the Basin and that its wells were designed to yield water with no impacts to the District's groundwater pumping capacity at low Basin water levels. Due to the historic drought conditions the OSY has been set at a very low level for the last four years. This has resulted in a 18% reduction of the District's annual production right as compared to the long-term average annual production right. Approximately 40% of water the District pumps from the Basin each year to meet its water system demand, requires the District to lease production rights and/or purchase replacement water. **Figure 1.3** displays the District's annual production right and the long term annual average of its production right.

Figure 1.3 District's Annual Production Rights (2002-2018)



The District is located within the service area of regional water supplier Upper San Gabriel Valley Municipal Water District (Upper District). The District relies upon Upper District to deliver replacement water for every acre foot of water produced over the District's annual production right. Upper District is a member agency of the Metropolitan Water District of Southern California (MWD), which is the agency that it purchases imported water from for replenishment purposes. The vast majority of imported water is delivered through the State Water Project (SWP) Delivery System. In the past, MWD provided this water at its replenishment water rate. Between 2007 and 2010, imported water at the replenishment rate was unavailable for purchase, but was available at the MWD tier 1 and tier 2 untreated water rates, which were substantially higher. As a result of

the import water pricing change, in May 2009, the rate for the Replacement Water Assessment, set by Watermaster, was increased from \$251.90 per acre foot to \$450.00. In May 2018, the Replacement Water Assessment was set at \$934.00 per acre foot for the 2018-19 production year, which equates to a \$682.10 per acre foot increase over the last nine years.

The District was able to cushion the effect of this increase by purchasing 2,000 acre feet of cyclic storage water (in 2009) at a rate of \$251.90 per acre foot. Cyclic storage water, when available, can be purchased by a producer that has a cyclic storage water agreement in place with Watermaster. Cyclic storage water is replenishment water that has already been delivered into the Basin, which can be used to offset future replenishment water obligations. This water has allowed the District to limit its replenishment water purchase to only 188 acre feet over the last nine years. Currently the District has 929 acre feet in its cyclic storage account. This water also provides a major benefit during times of drought, like we are currently facing. Over the last seven years, the District has also leased groundwater productions rights at a rate 8% to 10% lower than the cost for replacement water, which further reduced the impact of the rising cost of replenishment water. The future cost for replenishment water along with groundwater production assessments will continue to have a substantial financial impact on the District in years to come.

Water Quality and the Cost of Water Treatment

The area of the Basin where the District's wells draw water is contaminated with various contaminants, such as volatile organic compounds (VOC's) and perchlorate. In 2002, the District along with other water entities, entered into an agreement with the parties who were potentially responsible for the groundwater contamination. This agreement is known as the Baldwin Park Operable Unit Project Agreement (BPOU Agreement). Under this Agreement, the water from the District's well field is treated at the District's groundwater treatment facility before it enters the District's service area. Water leaving the facility meets all State and Federal drinking water regulations. The cost to construct, maintain and operate the treatment facility was and continues to be reimbursed by the potentially responsible parties, who are now known as the Cooperating Respondents (CRs). None of these treatment costs are paid for through the District's water rates.

The term of the BPOU Agreement was 15 years and was set to expire in May of 2017. The District, other water entities and the CRs negotiated an extension to the BPOU Agreement (referred to as the 2017 BPOU Agreement), which has secured continued funding of groundwater treatment at the District's well field for an additional ten years.

In 2018, District staff identified that levels of nitrate in the water produced from the District's well field were increasing. Although the levels of nitrate in the water are below the regulatory maximum contaminant level for nitrate, District staff recommends moving forward, in the next two years, with the addition of a nitrate treatment system at the District's groundwater treatment facility. The capital investment and operational cost of a nitrate treatment system will have a substantial financial impact on the District and the cost for water.

Customer Base and Water Usage

The 2,550 customer connections of the District are delineated into 6 different categories: residential, multi-family, institutional, commercial, industrial, irrigation & fire service. Dedicated fire service connections make up approximately 1.7% of the customer connections. The District bills its customers for water service and water usage on a bi-monthly basis. The District meters the water usage for each customer and bills for every hundred cubic feet (hcf) of water used (hcf =748 gallons), this is referred to as a unit of water.

Residential and multi-family connections make up approximately 83%. Residential single-family home connections comprise about 81% of all connections with multi-family accounting for 2%. The water use from these customer categories makes up approximately 58% of the water system demand. **Table 1.1** provides a summary of the number of active services by customer category and the percent of the overall water system demand for each category based on water consumption data from 2018.

Table 1.1 Number of Active Connections by Category and Percentage of Demand

Customer Category	Number of Connections	% of Connections	% of Water System Demand
Residential	1971	79.8%	45%
Multi-Family	54	2.2%	13%
Commercial	280	11.3%	15%
Industrial	7	0.3%	6%
Irrigation	86	3.5%	15%
Public Authority	27	1.1%	6%
Fire Service	44	1.8%	0%
Total	2469	100.0%	100%

Residential per capita water use in the District averaged 83 gallons per person per day in 2018. Over the last three years, single-family residential class customers used approximately 24 units of water, on average, each bi-monthly billing period. The average Customer's bi-monthly water bill in 2018 was approximately \$72.00 (\$35.00 monthly) and their annual cost for potable water service was \$432.00, which is less than 1% of the median household income within the District's service area.

Water Rate Adjustments

On July 18, 2006, the Board of Directors passed Resolution No. 178, which established water and service charge rates through 2010. This resolution also specifies that rates be reviewed on an annual basis. The adopted rate increases for the years 2006, 2007 and 2008 were implemented and had increased revenue as projected. In 2008 and 2009 the District minimized the impact of rising operating expenses through the following cost saving efforts:

- Grant Funding for New Well (2008)
- Cyclic Storage Water Purchase (2009)

Due to these cost savings efforts, the Board of Directors passed Resolution No. 193 on September 9, 2009 which canceled the scheduled rate increases for 2009 and directed Staff to complete a water rate study prior to making any other water rate adjustments.

In July 2010, the Board of Directors established a Reserve Fund Policy for the District. This policy is an important tool that guides Staff in its planning of the District's financial resources. In May 2012, the Reserve Fund Policy was updated to add reserve funds for water system connection fees and retiree health benefits.

In 2010, the District's Board of Directors directed Staff to conduct an in-house water rate study, which was completed in April 2011. As part of the study, staff provided a recommendation for water rates, which would generate sufficient revenue to meet the cost of providing water service to its customers over a five-year period. The final recommendation was to adopt a multi-year (5 year) water rate adjustment plan that would avoid drastic increases to water rates. Water rate adjustments were developed and a notice to all customers of the proposed increase to water rates was provided as required by articles XIIC and XIID of the California Constitution (Proposition 218). The recommended rate adjustment was approximately 24%, over a five-year period, for the average customer. The rate adjustments were adopted by unanimous vote of the Board of Directors on August 22, 2011 with the first rate adjustment effective in September 2011 with subsequent adjustments instituted in September of each year with the 5th year adjustment instituted in September 2015.

In 2017, the District initiated another water rate study and comprehensive cost of service analysis. This study was completed by Raftelis Financial Consultants in June of 2018. The final recommendation was to adopt a multi-year (5 year) water rate adjustment plan. Water rate adjustments were developed as part of the study and a notice to all customers of the proposed increase to water rates was provided in August of 2018. Substantial increases in the District's operational expenses, as described below, were the major factors supporting the need for an increase to water rates and charges:

Cost of Water – The District is fortunate to have rights to a local groundwater source in the Main San Gabriel Basin (“Basin”), but any water the District pumps over its allotment must be replaced to maintain water levels in the Basin by leasing rights or purchasing imported water. The cost for this replacement water has increased by over twenty-three percent (23%) in the last four years.

Groundwater Management – A new groundwater pumping assessment has been put into effect by the Main San Gabriel Basin Watermaster in order to secure additional water resources to maintain water levels in the Basin. This assessment will have a large cost impact on the District and all water providers that pump groundwater from the Basin in the San Gabriel Valley.

Capital Improvements – The District continuously invests in capital improvement projects that improve the performance of the water system or extend the life of existing facilities and equipment to avoid more expensive emergency repairs. In 2017 the District updated its Ten-Year Water

Master Plan which identified necessary improvements and prioritized projects based on their need and benefit.

The recommended rate increase is approximately 38% over a five-year period, for the average customer. The rate adjustments were adopted by unanimous vote of the Board of Directors on October 15, 2018. The first year's rate adjustment became effective the first billing cycle following October 15, 2018, with subsequent adjustments to be instituted in October of each year with the 5th year adjustment instituted in October 2022.

The Budget

This Budget has been designed to help fulfill the District's Mission to provide high quality water along with courteous and responsive service at the most reasonable cost to our customers. The Budget is intended to support the priorities and policies of the Board of Directors as reflected in the District's Mission Statement and serve as a policy document, a financial plan, a communications device and an operations guide. It provides a comprehensive summary of District activities and capital improvement projects proposed for year ending December 31, 2019. The District is embarking on its District's 95th year of service to the community, which comes with significant challenges. Continued prudent planning of the District is paramount in positioning the District to handle these challenges long into the future.

The District's budget is prepared on a full accrual basis of accounting generally accepted in the United States, which is consistent with the District's audited financial statements. Revenues are recorded at the time they are earned and expenses are recorded at the time the liability is incurred. The intent of the District is to establish water rates sufficient to provide for payment of all operations and maintenance expenses along with capital improvements. The annual goal is to present a balanced budget (projected expenses equal to or less than projected revenues) to the Board of Directors for adoption.

The preparation and adoption of a comprehensive budget and operating plan is essential for the sound management and financial administration of the District. As an enterprise type of utility, the District is similar to a commercial operation whose expenditures may vary during the year in response to the timing and level of customer service demand. Water service demand is primarily influenced by water consumption practices, weather factors and the continued growth in the number of customers served. Budget objectives must therefore be structured to respond to fluctuating service demands. Activities are projected from historical data as a baseline to determine the appropriate funding level. Decisions made throughout the year by the Board of Directors and the General Manager is balanced between meeting budget objectives and budgetary constraints.

Direction of the District and Financial Forecast

Looking out beyond 2019, it is necessary to identify any significant increase in expenses that the District will need to be prepared for, either by managing reserves or increasing revenues. In preparing the annual budget, District Staff also projects the annual revenue and operating expenses (cash items) out for five years. These projections include all operating costs and capital

improvement investments but exclude depreciation and noncurrent liabilities. Summarized below are a few District ventures that will have substantial impact on the five-year projection of revenue and expenses.

Recycled Water Project

The construction of a recycled water system is of importance over the next year and will require the District, for the first time in several decades, to obtain a loan to finance such a project. The investment in a recycled water system will deliver recycled water to several irrigation customers and replace the use of drinking water for irrigation.

The recent drought has made it clear that reliance on imported water for groundwater replenishment is not the best long-term solution for the regions' water supply needs. By incorporating recycled water into the District's overall supply, we would reduce our dependence on this expensive water source.

The District has partnered with Upper San Gabriel Valley Municipal Water District to secure a \$428,000 grant from the State Department of Water Resources for Phase 1 of a Recycled Water System Project. The projected cost of Phase 1 is \$2,000,000. The grant will cover approximately 25 percent of the estimated cost of Phase 1, which is expected to serve 50 acre feet per year of recycled water, to be purchased indirectly from Los Angeles County Sanitation Districts, to serve irrigation customers on Don Julian Avenue.

The District had also planned on a Phases 2 and 3 to deliver an additional 140 acre feet per year. During 2017 the District was informed by the Los Angeles County Sanitation Districts that the availability of recycled water for the District's Phase 2 and Phase 3 was uncertain. They also informed the District that recycled water for the District's Phase 1 may be delayed due to permitting issues associated with decreasing recycled water discharges into the San Gabriel River as a result of increasing the use of recycled water for irrigation. At this time, District staff is uncertain if or when recycled water for Phase 1 of the District's Recycled Water Project will be made available. Phase 2 and 3 have been put on hold until the availability of 140 AF of recycled water annually, can be secured.

The current cost to produce 50 acre feet of water that is over the District's annual production right is approximately \$50,000. The District will **need** to secure a loan along with any other available grant funding to fund this project, which would otherwise not be cost effective. The assumptions of the Recycled Water Project cost and the associated debt service, is included in the five-year forecast. This new drought resistant source of water improves long-term water supply reliability for all the District's customers. The estimated cost of the Recycled Water System Project, loan proceeds, loan payment and other grant funding are included in the 5-year revenue and expense projections.

Puente Valley Operable Unit Intermediate Zone Project

The District prides itself on its efforts over the past 25 years to provide groundwater cleanup (treatment) in the Main San Gabriel Groundwater Basin. In fact, the District was the first water agency in the San Gabriel Valley to provide multi-barrier treatment for various contaminants at its groundwater treatment facility, which kick started other groundwater treatment projects in the

Valley. Over the years, the District's groundwater treatment plant has removed tons of contaminants. Our District's overall goal is to leave the groundwater basin free of contamination for future generations, so that it may continue to be used to meet the needs of its residents.

In mid-2014, the District was presented with an opportunity to further make a difference in remediating groundwater contamination in the Main San Gabriel Basin, more specifically the Puente Valley area. Under an order by US EPA, several industrial companies have been planning for several years to construct a highly efficient groundwater treatment system. This system would be comprised of 50 monitoring wells, 7 production wells, and multiple treatment technologies. In 2015, a property was purchased, by the lead industrial company, to construct the groundwater treatment facility. This property is located within the District's service area and in close proximity to the District's water distribution facilities. Since District staff already has experience operating a similar groundwater treatment system, the District has agreed to operate the Puente Valley Operable Unit Intermediate Zone (PVOU IZ) treatment facility. The plan was for the District to receive fully treated water, which meets all State and Federal drinking water standards, into its water system to utilize this water as a back-up supply for the District and for the neighboring Puente Basin Water Agency.

In November 2014, the District, the Puente Basin Water Agency, and the lead industrial company signed a Term Sheet to move forward with plans for the District to operate and deliver water from the proposed groundwater treatment plant. The plant will need to be operated on a continual basis and any surplus water in excess of the needs of the District was planned to be conveyed to the Puente Basin Water Agency.

In 2017 the PVOU IZ project was been modified with respect to the delivery of treated water. The treated water is now planned to be delivered to the District, who will in turn deliver a certain amount to neighboring Suburban Water Systems. The other components of the project remain unchanged.

The new treatment facility will improve water quality in the groundwater Basin, provide an additional emergency water supply for the community of La Puente, and create an additional revenue source for the District. The revenue that will be received by the District for conveying water and operating the plant will help keep the District water rates affordable. The groundwater treatment system and associated improvements are anticipated to be constructed over the next years with groundwater treatment starting in 2020. The revenue anticipated from the District's involvement in this project is included in the five-year revenue projections.

Groundwater Treatment System for Nitrate Removal

Over the last year, District staff identified that levels of nitrate in the water produced from the District's well field were increasing in an abnormal trend, as compared to last 5 years. Although the levels of nitrate in the water are below the regulatory maximum contaminant level, District staff recommends moving forward, in the next two years, with the addition of a nitrate treatment system at the District's groundwater treatment facility. In 2019, District staff recommends the completion of a preliminary design report (PDR) to identify the most cost-effective nitrate treatment system to install at the District's groundwater treatment facility. The PDR will also

identify capital investment required to construct the recommended system and the annual operational and maintenance cost of the system as well.

Depending on the findings of the PDR the District will seek any available grants and may need to seek a loan for this project as well. The rough estimated cost of a nitrate treatment system, loan proceeds, loan payment and grant funding are included in the 5-year revenue and expense projections.

Table 1.2 provides a summary of the five-year forecast of the District’s expenses and compares it to the projected revenues.


Table 1.2 Five Year Forecast of Revenue and Expenses

	2018	2019	2020	2021	2022	2023
Revenue	\$ 4,633,200	\$ 6,697,700	\$ 7,999,800	\$ 4,604,000	\$ 4,892,600	\$ 5,151,500
Expenses	\$ 4,653,200	\$ 6,779,300	\$ 8,421,500	\$ 5,146,000	\$ 5,208,000	\$ 5,488,000
Net Gain/Loss	\$ (20,000)	\$ (81,600)	\$ (421,700)	\$ (542,000)	\$ (315,400)	\$ (336,500)

District’s Cash and Reserves

In May 2012, the Board of Directors adopted Resolution No. 208 which updated the policy for the management of the District’s cash and financial reserves. The Policy specifies what types of reserves the District shall maintain and what the minimum and maximum levels shall be for each reserve fund. **Figure 1.4** below provides a five-year projection of the cash and the reserve fund level based on the projected expenses and revenues from **Table 1.2**.

Figure 1.4 Five Year Projection of the District’s Total Cash and Reserve Fund Level



Reserve fund levels decline in 2019 & 2020, primarily due to the projected capital investments in the District’s Recycled Water Project & Nitrate Treatment System Project. In 2022, reserve levels start to decline. Staff projects that the recently adopted five-year water rate increase plan is vital in maintain adequate reserve fund levels and meeting the needs of the District’s Customers.

2019 Objectives

Special emphasis will be placed on accomplishing the following objectives during 2019.

- ❖ Recycled Water System Project
 - Complete Design of Phase 1
 - Confirm Recycled Water Availability
 - Complete Construction of Phase 1
 - Initiate Phase 1 Customer Retrofits
- ❖ Continue Involvement in the PVOU Intermediate Zone Project Planning
- ❖ Secure Groundwater Production Right Leases for Approximately 629 Acre Feet that Reduce the Impacts of Replacement Water Costs
- ❖ Continue Fulfill Contractual Obligation in Operating and Managing the City of Industry Waterworks System in a Cost-Effective Manner
- ❖ Secure Best Available Grants and Financing for the District's Capital Improvement Projects
- ❖ Complete Capital Improvement Projects

Executive Summary

A report of the significant findings and recommendations for the calendar year 2019 Budget are:

- ❖ Overall water system demand is projected to be roughly 1,580 acre-feet
- ❖ Annual Revenue is expected to be \$4,787,700
- ❖ Annual Expenditures are budgeted at \$4,68,300
- ❖ Capital Improvement/Outlay Projects are budgeted at \$2,095,000
- ❖ The District expects to receive grant and loan proceeds of \$1,800,000 to fund the District's Recycled Water Project
- ❖ The District expects to receive reimbursement for the estimated \$1.36 million O&M costs incurred in the operation of the treatment plant
- ❖ The District expects to receive \$265,900 in revenue from management fees for the operation and management of the City of Industry Waterworks System and the District's Groundwater Treatment Facility
- ❖ The District expects to receive \$215,000 in revenue from taxes and assessments
- ❖ District Reserve Funds are expected to decrease by \$81,600 through 2019

Water Operations Fund

The District's activities identified in this budget are designed to accomplish the District's Mission as it relates to water operations. For the calendar year 2019, the District will need a total operation budget of \$4,787,700 to carry out its Mission.

The District currently provides residential, commercial and industrial water through a production and distribution system valued at \$7,871,662. The system consists of three active wells, eleven interagency water connections, three reservoirs with a combined storage capacity of 4.9 million gallons, 5 booster stations and more than 32 miles of water mains. During 2019, it is projected that the District will deliver over 1,580 acre feet of water to over 2,550 active service connections.

All of the revenues and expenses that allow the District to function flow either directly or indirectly through the Water Operations Fund. The Water Operations Fund's source of revenue consists of water sales, miscellaneous billing, property taxes, management fees and interest earned on Water Operations Fund related investments.

The Water Operations Fund exists to finance operations, maintenance, repair, supplies, depreciation, contingencies, personnel compensation related to water operations, capital improvements and to provide a catastrophic restoration reserve.

The Budget Summary details the projected Water Operations Fund revenues and expenditures for 2019 and compares those revenues and expenditures with the estimate for year-end 2018.

Water Revenue - Operational

Water Sales and Service Charges:

Water sales and service charges are the major sources of revenue for the District. These sales are the result of the District's normal meter reading and billing activities for all classes of water to all active service connections. The distribution of sales provides 38 percent as fixed sales allocated to the service charges on the basis of meter capacity and the remaining 62 percent being variable sales and allocated to the commodity charges. The District forecasts water sales at \$1,340,00. Water sales revenue is predicated on a projected average water usage of 1,580 acre feet to over 2,550 water services and includes construction water and miscellaneous billings.

Operational Revenue Related to the District's Groundwater Treatment Facility

The District owns and operates a groundwater treatment plant within the Main San Gabriel Basin for the removal of various contaminants. The United States EPA has identified this contaminated area of the Basin as BPOU and has named those parties that are potentially responsible, also known as the Cooperating Respondents, for the contamination in this area of the Basin. The construction and ongoing operating cost of the District's treatment plant is reimbursable per the BPOU Project Agreement entered into by the Cooperating Respondents, Main San Gabriel Basin Watermaster, San Gabriel Basin Water Quality Authority and the Water Entities; which the District is a party to. As detailed in the Proposed 2019 Budget for the District's Treatment Plant, the District anticipates the operation and maintenance expense for the Treatment Plant to be \$1.36 million dollars, all of which will be reimbursed to the District by the Cooperating Respondents.

Water Revenue – Non-Operational

Interest:

For calendar year 2019, District staff forecasts interest on Water Operations Fund related investments of \$28,800. The estimate is predicated on a projection of historical data and its relationship to current interest rates.

Other Non-Operational Revenues:

This includes a total of \$215,000 from Property Taxes; \$265,900 for Fees related to the management of the Treatment Plant and the City of Industry Water Works System; \$1,050,000 from Service Fees related to labor reimbursement, \$36,800 from Rental Revenue, \$300,000 from Prop 84 Grant Funds and \$1,500,000 from Recycled Water Project Loan proceeds.

Water Expenditures

Personnel (Salaries and Benefits):

In order to maintain high quality service within the District's service area, fulfill contractual obligations to manage and operate the City of Industry Waterworks System, continue the District's involvement in the PVOU IZ Project and operate the District's Groundwater Treatment Facility, a total of 13 full-time employees and 2 part-time employees will be needed.

(Field Operations) Transmission, Distribution, Treatment and Supply 8.5

(Office and Management) Customer Service and Administration 6.5

In calendar year 2019, the District will need a personnel compensation budget of \$1,288,600 for salaries and payroll taxes related to meeting the requirements of water distribution, water treatment & supply, customer service and administrative functions for the District, CIWS, BPOU Treatment Plant Operations and PVOU IZ; \$36,700 for Governing Board of Directors. The District's 2019 projection for the total cost of health benefits for current directors and employees is \$389,000 and for retirees is \$42,000. This year's Budget also includes prefunding of Post-Retirement Health Benefits in the amount of \$100,000, which will be partially off-set by revenue generated from labor cost reimbursement from the CIWS and Treatment Plant Operations.

Supply and Treatment:

Water Supply and Treatment make up the variable costs of the District. These costs are generally defined as the annual operating expense to purchase and lease imported water and pump local groundwater to satisfy customer service demand. Variable costs are sensitive to operating factors that are beyond the District's control. These factors include weather, new construction, pricing or incentive programs offered by other agencies, cost of treatment chemicals and materials, energy costs and changes in efficiency of existing equipment. The budget amount can be considered as the best projection of annual costs based on an average weather, growth and consumption. For the calendar year 2019, the District will need a total of \$1,780,700 for the Supply and Treatment costs.

Other Operating Expenses:

These program costs make up a portion of the fixed operating or "overhead" costs required to maintain the District's plant sites and water distribution system (facilities). This includes costs for services, materials, vehicles and equipment for the repair, maintenance and operation of these facilities. For the calendar year 2019, the District will need a total of \$481,500 for Other Operating Expenses.

General and Administrative:

These program costs are "overhead" costs required to maintain District operations as they relate to customer service and administrative functions of the District. This includes costs for office supplies, office building maintenance, office equipment, customer billing, insurance, professional services, public outreach and conservation programs. For the calendar year 2019, the District will need a total of \$412,000 for General and Administrative costs.

Capital Improvements and Capital Outlay

The District is committed to enhancing the condition of its water system through investments in capital improvement projects. These investments will ensure that the water system will deliver high quality water to its customers long into the future. These investments will also ensure that the District's personnel will have the necessary tools to carry out their functions. Capital Improvements and Outlay may include expenditures for construction of new permanent capital facilities, replacement of existing facilities, purchasing fixed assets for various programs in the District and capital purchases necessary to maintain the quality of operations in the District.

Table 1.3 below is a summary for Capital Improvement and Capital Outlay expenses that are necessary to maintain high quality service for District Customers:

Table 1.3 2019 Capital Improvement Projects & Capital Outlay

Project	Description	Cost
Service Line Replacements	Replace Aging Plastic and/or Galvanized Service Lines as Needed	\$ 25,000
Valve Replacements	Replace Inoperable Valves as Needed	\$ 40,000
Fire Hydrant Replacements	Replace Inoperable Fire Hydrants as needed.	\$ 5,000
Other Improvements	Replace distribution system appurtenances as needed.	\$ 15,000
Scada Improvements	Assessment of current system and initiate improvements to software and hardware	\$ 50,000
Meter Read Collection System	Expand the Radio Meter Reading Collection System	\$ 20,000
New Pick-Up Truck	Purchase 1/2 Ton Pick-Up to Replace Fully Depreciated Pick-Up with over 120K Miles	\$ 40,000
Other Equipment and IT Equipment	Purchase of computer equipment and small construction equipment.	\$ 30,000
Ferrero Lane and Rorimer St. Improvements	Construct a new pressure regulating station to supply water from Zone 2 to the southeast portion of Zone 1 to improve fire flow and service reliability.	\$ 75,000
5th Avenue Waterline Improvement	Construct a new waterline from in 5 th avenue from Main Street to Workman to improve fire flow.	\$ 150,000
LP-CIWS Interconnection (Ind. Hills)	Design upgrades to an interconnection between the CIWS and the District to assist with the delivery of PVOU IZ treated water.	\$ 10,000
Hudson Plan Improvements	Design a new pump station for the delivery of PVOU IZ treated water to Suburban Water Systems and improvements to the District's existing pump station.	\$ 75,000
Well No. 5 Rehab (Design)	Complete design of new pumping equipment and sound enclosure for Well No. 5	\$ 25,000
Groundwater Treatment System – Nitrate Removal	Complete a preliminary design report for the addition of a Nitrate treatment system at the District's groundwater treatment facility.	\$ 85,000
Recycled Water System (Phase 1)	Complete design and Construct a Portion of a New Recycled Waterlines and Pump Station for 10 Irrigations Customers.	\$ 1,450,000

Total: \$ 2,095,000

Table 1.4
 La puente Valley County Water District Budget Summary
 Period Ending December 31, 2019

<u>DESCRIPTION</u>	COMBINED Proj. YE 2018	COMBINED BUDGET 2018	% OF BUDGET	LPVCWD PROPOSED 2019	TP PROPOSED 2019	COMBINED PROPOSED 2019	2019-2018 BUDGET VARIANCE
Total Operational Rate Revenues	\$ 2,020,400	\$ 2,031,000	99%	\$ 2,109,500	\$ -	\$ 2,109,500	\$ 78,500
Total Operational Non-Rate Revenues	2,311,100	2,454,300		1,014,500	1,361,400	2,375,900	(78,400)
Total Non-Operational Revenues	301,700	291,100	104%	302,300		302,300	\$ 11,200
TOTAL REVENUES	4,633,200	4,776,400	97%	3,426,300	1,361,400	4,787,700	11,300
Total Salaries & Benefits	1,959,000	1,959,600	100%	1,708,500	301,400	2,009,900	\$ 50,300
Total Supply & Treatment	1,634,400	1,714,200	95%	918,400	862,300	1,780,700	\$ 66,500
Total Other Operating Expenses	354,270	460,100	77%	314,300	167,200	481,500	\$ 21,400
Total General & Administrative	394,800	500,500	79%	381,700	30,500	412,200	\$ (88,300)
TOTAL EXPENSES	4,342,470	4,634,400	94%	3,322,900	1,361,400	4,684,300	49,900
TOTAL OPERATIONAL INCOME	290,730	142,000	205%	103,400	-	103,400	\$ (38,600)
Capital Improvements	(275,200)	(1,235,000)	22%	(2,025,000)	-	(2,025,000)	(790,000)
Capital Outlay	(35,500)	(50,000)	71%	(70,000)	-	(70,000)	\$ (20,000)
TOTAL CAPITAL	(310,700)	(1,285,000)	24%	(2,095,000)	-	(2,095,000)	(810,000)
INCOME (AFTER CAPITAL EXPENSE)	(19,970)	(1,143,000)	2%	(1,991,600)	-	(1,991,600)	(848,600)
Capital Reimbursement (OU Projects)				110,000		110,000	
Grant Proceeds	-	300,000	0%	300,000	-	300,000	\$ -
Loan Proceeds	-	500,000	0%	1,500,000	-	1,500,000	\$ 1,000,000
Loan Repayment	-	-	0%	-	-	-	\$ -
CHANGE IN CASH	(19,970)	(343,000)	6%	(81,600)	-	(81,600)	151,400
Contributed Capital (Developer)	238,870			-		-	
Add Back Capitalized Assets	310,700	1,285,000	24%	2,095,000		2,095,000	
Less Depreciation Expense	(380,000)	(560,000)	68%	(380,000)	(180,000)	(560,000)	
Less OPEB & Pension Liability Expense -	(181,000)	-		(10,000)		(10,000)	\$ (10,000)
NET INCOME (LOSS)	\$ (270,270)	\$ 382,000	-71%	\$ 1,513,400	\$ (180,000)	\$ 1,333,400	\$ 141,400

Table 1.5
La Puente Valley County District
Budget for Period Ending December 31, 2019

Description	2017 Actual	Projected YE 2018	2018 Budget	Variance from Budget	2019 Budget	2019 Budget- 2018 Budget
Operational Rate Revenues						
Water Sales	\$ 1,251,382	\$ 1,284,200	\$ 1,295,000	\$ (10,800)	\$ 1,340,000	\$ 45,000
Service Charges	604,424	604,900	608,500	(3,600)	636,000	27,500
Surplus Sales	35,769	43,400	38,000	5,400	40,000	2,000
Customer Charges	33,425	30,100	33,300	(3,200)	34,100	800
Fire Service	56,096	56,400	55,500	900	58,400	2,900
Miscellaneous Income	805	1,400	700	700	1,000	300
Total Operational Rate Revenues	1,981,901	2,020,400	2,031,000	(10,600)	2,109,500	78,500
Operational Non-Rate Revenues						
Management Fees	194,810	260,700	261,700	(1,000)	265,900	4,200
PVOU Service Fees (Labor)	-	16,400	42,900	(26,500)	40,000	(2,900)
<i>BPOU Service Fees (Labor)</i>		307,700	278,800	28,900	<i>301,400</i>	<i>22,600</i>
IPU Service Fees (Labor)		689,600	715,800	(26,200)	695,600	(20,200)
Other O&M Fees	65,461	12,500	13,000	(500)	13,000	-
Total Operational Non-Rate Revenues	260,271	1,286,900	1,312,200	(25,300)	1,315,900	3,700
Non-Operational Revenues						
Taxes & Assessments	230,516	210,000	215,000	(5,000)	215,000	-
Rental Revenue	34,988	36,000	36,100	(100)	36,800	700
Interest Revenue	27,436	28,800	17,000	11,800	28,800	11,800
Miscellaneous Income	76,053	21,900	18,000	3,900	16,700	(1,300)
Developer Fees	81,095	5,000	5,000	-	5,000	-
Total Non-Operational Revenues	450,088	301,700	291,100	10,600	302,300	11,200
TOTAL REVENUES	2,692,261	3,609,000	3,634,300	(25,300)	3,727,700	93,400
Salaries & Benefits						
Total District Wide Labor	497,621	1,152,600	1,142,700	9,900	1,195,800	53,100
Directors Fees & Benefits	117,385	119,220	117,300	1,920	116,600	(700)
Benefits	124,987	300,680	303,100	(2,420)	308,800	5,700
OPEB Payments	157,030	150,000	150,000	-	142,000	(8,000)
Payroll Taxes	43,150	91,500	90,600	900	92,800	2,200
Retirement Program Expense	64,566	145,000	155,900	(10,900)	153,900	(2,000)
Total Salaries & Benefits	1,004,737	1,959,000	1,959,600	(600)	2,009,900	50,300
For Analysis Purposes Only						
Offsetting Revenue	(50,000)	(1,033,700)	(1,057,500)		(1,057,000)	500
District Labor Net Total	954,737	925,300	902,100	23,200	952,900	50,800
Supply & Treatment						
Purchased & Leased Water	421,870	377,100	379,500	(2,400)	467,200	87,700
Power	149,637	155,500	157,000	(1,500)	163,700	6,700
Assessments	132,114	188,500	221,900	(33,400)	248,300	26,400
Treatment	4,079	3,600	6,000	(2,400)	6,700	700
Well & Pump Maintenance	12,188	22,100	32,700	(10,600)	32,500	(200)
Total Supply & Treatment	719,888	746,800	797,100	(50,300)	918,400	121,300
Other Operating Expenses						
General Plant	29,918	27,570	42,300	(14,730)	48,100	5,800
Transmission & Distribution	52,872	102,000	90,500	11,500	102,400	11,900
Vehicles & Equipment	14,669	30,200	30,300	(100)	31,800	1,500
Field Support & Other Expenses	30,329	48,600	68,500	(19,900)	69,000	500
Regulatory Compliance	28,754	34,300	51,500	(17,200)	63,000	11,500
Total Other Operating Expenses	156,543	242,670	283,100	(40,430)	314,300	31,200

Table 1.5
 La Puente Valley County District
 Budget for Period Ending December 31, 2019

Description	2017 Actual	Projected YE 2018	2018 Budget	Variance from Budget	2019 Budget	2019 Budget- 2018 Budget
General & Administrative						
District Office Expenses	37,453	42,000	61,800	(19,800)	64,100	2,300
Customer Accounts	20,907	18,500	20,400	(1,900)	25,000	4,600
Insurance	60,490	64,300	69,900	(5,600)	65,800	(4,100)
Professional Services	132,598	130,200	160,000	(29,800)	120,000	(40,000)
Training & Certification	29,068	42,000	37,700	4,300	37,500	(200)
Public Outreach & Conservation	15,717	34,500	32,500	2,000	32,500	-
Other Administrative Expenses	29,176	38,300	70,200	(31,900)	36,800	(33,400)
Total General & Administrative	325,409	369,800	452,500	(82,700)	381,700	(70,800)
TOTAL EXPENSES	2,206,578	3,318,270	3,492,300	(174,030)	3,624,300	132,000
TOTAL OPERATIONAL INCOME	485,683	290,730	142,000	148,730	103,400	(38,600)
CAPITAL, LOANS AND DEBT SERVICE						
Capital Improvements						
Zone 3 Improvements	(7,022)	(200,300)	(220,000)	19,700	-	220,000
Service Line Replacements	(33,456)	(47,200)	(20,000)	(27,200)	(25,000)	(5,000)
Valve Replacements	(13)	(9,600)	(10,000)	400	(40,000)	(30,000)
Fire Hydrant Repair/Replacements	(178)	(11,900)	-	(11,900)	(5,000)	(5,000)
Meter Read Collection System & Meter Replac	(42,141)	(200)	(35,000)	34,800	(20,000)	15,000
SCADA Improvements	-	-	(15,000)	15,000	(50,000)	(35,000)
Main & 1st Street Building Retrofit	-	(4,100)	(35,000)	30,900	-	35,000
Ferrero Lane and Rorimer St. Improvements	-	-	-	-	(75,000)	(75,000)
5th Avenue Waterline Improvement	-	-	-	-	(150,000)	(150,000)
LP-CIWS Interconnection (Ind. Hills)	-	-	-	-	(10,000)	(10,000)
Hudson Plant Improvements	-	-	-	-	(75,000)	(75,000)
Well No. 5 Rehab (Design)	-	-	-	-	(25,000)	-
Nitrate Treatment System	-	-	-	-	(85,000)	(85,000)
Phase 1 - Recycled Water System	-	(1,900)	(900,000)	898,100	(1,450,000)	(550,000)
Phase 2 - Recycled Water System	-	-	-	-	-	-
Other Improvements	-	-	-	-	(15,000)	(15,000)
Total Capital Improvements	(82,810)	(275,200)	(1,235,000)	959,800	(2,025,000)	(790,000)
Capital Outlay						
Truck(s)	(39,731)	(35,500)	(40,000)	4,500	(40,000)	-
Other Equipment	-	-	(10,000)	-	(10,000)	-
IT Equipment	-	-	-	-	(20,000)	(20,000)
Total Capital Outlay	(39,731)	(35,500)	(50,000)	4,500	(70,000)	(20,000)
TOTAL CAPITAL	(122,541)	(310,700)	(1,285,000)	964,300	(2,095,000)	(810,000)
INCOME (AFTER CAPITAL EXPENSE)	363,142	(19,970)	(1,143,000)	1,123,030	(1,991,600)	(848,600)
Funding & Debt Repayment						
Capital Reimbursement (OU Projects)	-	-	-	-	110,000	-
Grant Revenue	-	-	300,000	(300,000)	300,000	-
Loan Proceeds	-	-	500,000	(500,000)	1,500,000	1,000,000
Loan Payments	-	-	-	-	-	-
CASH DIFFERENCE	363,142	(19,970)	(343,000)	323,030	(81,600)	151,400
Contributed Capital	210,130	238,870	-	238,870	-	-
Add Back Capitalized Assets	122,542	310,700	1,285,000	(974,300)	2,095,000	810,000
Less Depreciation Expense	(360,602)	(380,000)	(380,000)	-	(380,000)	-
Less OPEB Expense - Not Funded	(71,263)	(10,000)	(12,800)	2,800	(10,000)	2,800
NET INCOME (LOSS)	\$ 263,949	\$ 139,600	\$ 549,200	(648,470)	\$ 1,623,400	\$ 1,074,200

Table 1.6
 La Puente Valley County Water District
 BPOU Treatment Plant Budget
 Period Ending December 31, 2019

Description	2017 Actual	Projected YE 2018	2018 Budget	Variance from Budget	2019 Budget	Difference 2019 Budget- 2018 Budget
Operational Non-Rate Revenues						
Reimbursements from CR's	\$ 1,189,748	\$ 1,331,900	\$ 1,420,900	\$ (89,000)	\$ 1,361,400	\$ (59,500)
Miscellaneous Income	-	-	-	-	-	-
Total Non-Operational Revenues	1,189,748	1,331,900	1,420,900	(89,000)	1,361,400	(59,500)
Salaries & Benefits						
<i>BPOU TP Labor (1)</i>	282,605	307,700	278,800	\$ 28,900.00	301,400	22,600
Contract Labor	-	-	-	-	-	-
Total Salaries & Benefits	282,605	307,700	278,800	28,900	301,400	22,600
Supply & Treatment						
NDMA, 1,4-Dioxane Treatment	195,827	211,300	170,000	41,300	218,200	48,200
VOC Treatment	25,374	1,800	17,800	(16,000)	20,000	2,200
Perchlorate Treatment	315,421	425,200	415,000	10,200	344,000	(71,000)
Other Chemicals	17,829	15,500	16,600	(1,100)	17,500	900
Treatment Plant Power	174,703	192,500	202,700	(10,200)	200,200	(2,500)
Treatment Plant Maintenance	19,347	21,300	75,000	(53,700)	42,000	(33,000)
Well & Pump Maintenance	16,315	20,000	20,000	-	20,400	400
Total Supply & Treatment	764,816	887,600	917,100	(29,500)	862,300	(54,800)
Other Operating Expenses						
General Plant	13,632	16,900	45,000	(28,100)	40,000	(5,000)
Vehicles & Equipment	10,413	12,000	10,000	2,000	12,200	2,200
Field Support & Other Expenses	-	2,400	15,000	(12,600)	15,000	-
Regulatory Compliance	96,395	80,300	107,000	(26,700)	100,000	(7,000)
Total Other Operating Expenses	120,440	111,600	177,000	(65,400)	167,200	(9,800)
General & Administrative						
District Office Expenses	-	-	10,000	(10,000)	2,500	(7,500)
Insurance	9,757	16,400	18,000	(1,600)	18,000	-
Professional Services	12,130	8,600	20,000	(11,400)	10,000	(10,000)
Total General & Administrative	21,887	25,000	48,000	(23,000)	30,500	(17,500)
TOTAL EXPENSES	1,189,748	1,331,900	1,420,900	(89,000)	1,361,400	(59,500)
<i>TOTAL EXPENSES (Minus Labor)</i>	<i>907,143</i>	<i>1,024,200</i>	<i>1,142,100</i>		<i>1,060,000</i>	
TOTAL OPERATIONAL INCOME	-	-	-	-	-	-
Depreciation Expense	(165,346)	(171,000)	(180,000)	9,000	(180,000)	-
Total Non-Cash Items (Dep. & OPEB)	(165,346)	(171,000)	(180,000)	9,000	(180,000)	-
NET INCOME (LOSS)	\$ (165,346)	\$ (171,000)	\$ (180,000)	\$ 9,000	\$ (180,000)	\$ -

(1) The labor expense depicted here is the amount of labor billed to the BPOU in which the District receives reimbursement which is shown on Table 1.5 in operational non-rate revenue (BPOU Service Fees).

Memo



To: Honorable Board of Directors
From: Roy Frausto, Engineering & Compliance
Meeting Date: December 18, 2018
Re: Engineering & Compliance Report – November 2018

CAPITAL PROJECTS

1. LPVCWD Recycled Water Project –
 - Staff will provide information through a verbal report.
2. LPVCWD PVOU IZ Project and SZ-South Project –
 - Staff received a revised draft copy of the Section 4 document of the 97-005 report for the PVOU IZ treatment facility on October 15, 2018. Staff concluded the review and provided comments to Northrop
 - Staff and District Counsel reviewed and commented on the draft term sheet with respect to an Operation Services Agreement for the SZ PVOU treatment system. A final draft is expected to be presented in January 2019
 - Construction crews began grading and exploratory excavations at the project site
3. LPVCWD Banbridge Pump Station Retrofit Project –
 - Staff is happy to report that both pumps successfully pumped at their design rate and performed as expected
 - Staff met with the Lievanos to discuss existing structures exterior color and pending aesthetic improvements

DEVELOPMENTS

1. CIWS: 13814 Valley Blvd (McDonalds) – Staff installed a 4-inch fire service and a 2-inch domestic service in support of an existing McDonalds restaurant building retrofit.
2. CIWS: 13551, 13553 and 13563 Don Julian Rd. (3 units) – Staff is installed three (3) new 1-inch water services to support accessory dwelling developments to three existing homes.
3. CIWS: 419 S 5th Ave - Staff is scheduled to install a new 1-inch water services to support a mobile housing unit at an existing property.
4. LPVCWD: Star Theatre Property (22 Condo Development) – A focused draft EIR was completed by the City of La Puente. The focused draft EIR is available for public review during regular business hours at City Hall and other various locations.
5. LPVCWD: 15921 Sierra Vista Court – Currently, City staff advised that a proposed grading plan was approved along with the retaining wall. It is anticipated that the request to construct 5 water services in support of the 5-unit development will be received in the next coming months.

SPECIAL/OTHER PROJECTS

1. LPVCWD: 17351 Main St – District staff conducted a cross connection control survey at the La Villa Puente Apartments and concluded that the onsite fire and domestic systems are interconnected. Provided these findings, staff sent a letter to the property manager advising the need of two backflow prevention devices to protect the existing 6-inch domestic meter and 6-inch fire service. Staff has scheduled an in person meeting to further discuss the scope of work and construction cost estimate.
2. Nitrate Levels – Provided the current levels (See **Enclosure 1**) of Nitrate at the District’s well field, staff is moving forward with acquiring a preliminary design report (PDR) to evaluate the different treatment options for Nitrate.
 - Staff drafted a Request for Qualifications (RFQ) as an initial step to qualify Engineering firms to submit future proposals with respect to drafting the PDR. The RFQ’s are due by January 4, 2019.
3. LPVCWD Sanitary Survey – On October 29, 2018, the State Water Resources Control Board Division of Drinking Water (DDW) conducted their sanitary survey of our District’s water system. Staff received a letter from DDW with respect to the 2018 Sanitary Survey and provided the following comments:
 - Sample Wells 2, 3 and 5 for SOCs and Well 2 for gross alpha and uranium by Dec. 31, 2018
 - Physically disconnect Well 4 from the distribution system or properly destroy Well 4 per DWR Bulletins 74-81 and 74-90 as Well 4 may serve as a conduit for groundwater contamination
4. GETS/WPS – Staff applied and received approval for the Government Emergency Telecommunications Service (GETS) and Wireless Priority Service (WPS). The services are administered by the Dept. of Homeland Security, which in summary provide priority communication capabilities to landlines and cell phones to key national security and emergency preparedness personnel during natural or man-made disasters.
5. School (K-12) Lead Sampling – Staff contacted Basset Unified School District and Whittier School District representatives to discuss lead sampling at Don Julian Elementary and Wallen L. Andrews Elementary to comply with AB 746 by July 1, 2019.
 - Staff sampled for lead at Don Julian Elementary on December 12, 2018
 - Staff sampled for lead at Wallen L. Andrews Elementary on December 6, 2018
6. CIWS Permit Amendment – Staff received the final permit amendment (enclosed as **Enclosure 2**) from DDW with respect to the CIWS system on November 16, 2018.

Enclosures

- *Enclosure 1: November/December 2018 Nitrate Levels*
- *Enclosure 2: 2018 CIWS Permit Amendment*

**SP 6 and SP 10
Nitrate Concentrations
EPA Method 300.0
MCL = 10 mg/l**

Nitrate Concentrations November/December 2018				
Date	SP 10	SP 6	Well	Comments
11/1/18	5.6	5.3	Well 5	New Resin Change Out
11/5/18	7.8	7.8	Well 5	
11/8/18	7.8	7.8	Well 5	
11/13/18	8.0	8.0	Well 5	
11/15/18	8.0	8.0	Well 5	
11/19/18	8.0	8.0	Well 5	
11/26/18	7.7	7.7	Well 5	
11/29/18	8.2	8.2	Well 5	
12/3/18	8.0	8.0	Well 5	
12/6/18	7.9	7.9	Well 5	
AVERAGE	7.7	7.7		
MINIMUM	5.6	5.3		
MAXIMUM	8.2	8.2		

NOTES:

All units reported in milligrams per liter (mg/l)

MCL = Maximum Contaminant Level



112 N First St.
La Puente, CA 91744

Enclosure 1

State Water Resources Control Board

Division of Drinking Water

November 15, 2018

Mr. Greg B. Galindo
General Manager
Industry Public Utilities
112 N. First Street
City of Industry, CA 91744

Dear Mr. Galindo:

SYSTEM 1910029 – CITY OF INDUSTRY WATERWORKS SYSTEM REVISED 2018 OPERATING PERMIT

On January 11, 2018, James Ko from our office conducted a sanitary survey of the City of Industry Waterworks System (City), with the assistance of you, Mr. Cesar A. Ortiz, Water Treatment & Supply Supervisor, and Mr. Roy Frausto, Engineering & Compliance Manager.

In addition to the sanitary survey, the attached revised full permit No. 04-07-18P-002 is issued to the City's water system because there have been numerous changes since the original full permit was issued on March 22, 2001. The permit includes specific provisions and appendices. Please review the permit and let us know if there are any comments.

A public water system may file with the State Water Resources Control Board (State Water Board) a petition for reconsideration of a decision by the Deputy Director to issue, deny or amend a permit. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the permit, permit amendment or decision. The date of issuance is the date when the Division of Drinking Water mails or serves a copy of the permit, permit amendment, or decision, whichever occurs first. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

The courtesy extended to our staff and the Division is greatly appreciated. If you have questions regarding this letter, please contact Mr. James Ko at (818) 551-2007 or me at (818) 551-2022.

Sincerely,

A handwritten signature in blue ink, appearing to read "Dmitry Ginzburg", followed by a long horizontal line extending to the right.

Dmitriy Ginzburg, P.E.
District Engineer
Hollywood District

Enclosure

Enclosure

WATER PERMIT NO. 04-07-18P-002

City of Industry Waterworks System

**Los Angeles County
System No. 1910029**

November 2018



CALIFORNIA

Water Boards

**STATE WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER**

STATE OF CALIFORNIA

DOMESTIC WATER SUPPLY PERMIT

Issued To

The City of Industry Waterworks System

1910029

By The

Division of Drinking Water
California State Water Resources Control Board



PERMIT NUMBER: 04-07-18P-002

DATE: November 15, 2018

WHEREAS:

- I. The *Division of Drinking Water* revised *the City of Industry Waterworks* water system's operating permit issued in March 2001.
- II. This public water system is known as *the City of Industry Waterworks System (hereinafter, City)* whose headquarters is located at *112 N. First Street, P.O. Box 3136, La Puente, CA 91744*.
- III. The legal owner of *the City of Industry Waterworks* water system is *the City of Industry; however, the La Puente Valley County Water District is contracted by the City of Industry to maintain, operate and monitor the water system. The City of Industry Waterworks System*, therefore, is responsible for compliance with all statutory and regulatory drinking water requirements and the conditions set forth in this permit.
- IV. The public water system for which the permit is being revised is described briefly below (a more detailed description of the permitted system is described in Section **1.2** of the attached Permit Report):

The facilities, two purchased water connections, one water reservoir, one booster station with three booster pumps, and various pipelines and appurtenances as required.

- V. The service area of **the City of Industry Waterworks System** shall be shown on the service area map in **Appendix A** of the Permit Report

And WHEREAS:

- I. All of the required information relating to the operation of **the City of Industry Waterworks System's** has been submitted.
- II. The Division of Drinking Water has evaluated all of the information submitted and has conducted a physical investigation of **the City of Industry Waterworks System's** water system.
- III. The Division of Drinking Water has the authority to issue domestic water supply permits pursuant to Health and Safety Code Section 116540.

THEREFORE: The Division of Drinking Water has determined the following:

- I. **The City of Industry Waterworks System's** meets the criteria for and is hereby classified as a **community** water system.
- II. The applicant has demonstrated that **The City of Industry Waterworks System's** has sufficient source capacity to serve the anticipated water demand for at least **10** years.
- III. The design of the water system complies with the Water Works Standards and all applicable regulations.
- IV. The applicant has demonstrated adequate technical, managerial, and financial capacity to operate reliably the proposed water system.
- V. Provided the following conditions are complied with, **The City of Industry Waterworks System** should be capable of providing water to consumers that is pure, wholesome, and potable and in compliance with statutory and regulatory drinking water requirements at all times.
- VI. The City of Industry Waterworks is hereby issued this domestic water supply permit to operate the City of Industry Waterworks Water System.
- VII. **The City of Industry Waterworks** shall comply with the following permit conditions:

GENERAL

1. **The City of Industry Waterworks** shall comply with all state laws applicable to public water systems and any regulations, standards, or orders adopted thereunder.
2. All water supplied by **the City of Industry Waterworks** for domestic purposes shall meet all Maximum Contaminant Levels (MCLs) established by the Division of Drinking Water. If the water quality does not comply with the California Drinking Water Standards, treatment shall be provided to meet standards.
3. The only sources approved for domestic water supply are the following:

Table 1: Active Groundwater Source

Sources	PS Code	Status	Capacity (gpm)
Well No. 5	1910029-007	Active	1,200

Table 2: Purchased Water Sources

No.	Connection	Source	Size	Flow Direction	Capacity (gpm)	Status
1	SGVWC Lomitas Reservoirs	GW	12"	SGVWC to City Zone 1	2,000	Active
2	SGVWC Workman Mill	GW	10"	SGVWC to City Zone 1	2,000	Active
3	SGVWC Salt Lake	GW	2"	SGVWC to City Zone 1	50	Active
4	LPVCWD Industry Hill PS 1 (Hill St.)	GW	16"	LPVCWD to City Zone 1	2,000	Emergency
5	LPVCWD Valley Blvd & Proctor Ave.	GW	14"	LPVCWD to City Zone 1	2,000	Emergency
6	LPVCWD Industry Hills PS 3	GW	12"	LPVCWD to Industry Hills	1,200	Emergency
7	LPVCWD Industry Hills Reservoir	GW	8"	Bi-Directional (Industry Hills)	400 to City	Active
8	LPVCWD Holguin Place	GW	4"	City to LPVCWD	195	Active

No.	Connection	Source	Size	Flow Direction	Capacity (gpm)	Status
9	LPVCWD San Jose Ave & Holguin Place	GW	12"	City to LPVCWD	2,000	Emergency

4. There are no approved treatment processes in **the City of Industry Waterworks** water system.
5. No changes, additions, or modifications shall be made to the sources or treatment processes outlined in Provisions 3 through 4 unless an amended water permit has first been obtained from the Division.

WATER QUALITY

6. **The City of Industry Waterworks** shall ensure that monitoring of all active sources is conducted in accordance with the vulnerability assessment issued by the Division of Drinking Water.

OPERATOR CERTIFICATIONS

7. **The City of Industry Waterworks** water system is not required to have treatment operators, as pursuant to Title 22, Chapter 13, Article 2, Section 63770 of the California Code of Regulations, certified distribution system operators may determine chemical dosage rates for distribution residual maintenance if needed.
8. **The City of Industry Waterworks** distribution system shall be operated by personnel who have been certified in accordance with Chapter 13, Title 22, CCR, Operator Certification Regulations. The chief and shift operator(s) for the distribution facilities shall have, at minimum, D2 and D1 certification, respectively.

CROSS-CONNECTION CONTROL PROGRAM

9. The City of Industry Waterworks shall comply with Title 17, CCR, to prevent the water system from being contaminated by possible cross-connections. The City of Industry Waterworks shall maintain a program for the protection of the domestic water system against backflow from premises having dual or unsafe water systems in accordance with Title 17. All backflow preventers shall be tested at least annually.

DIRECT ADDITIVES

10. **The City of Industry Waterworks** shall only use additives that have been tested and certified as meeting the specifications of NSF International/American National Standard Institute (NSF/ANSI) Standard 60. This requirement shall be met under testing conducted by a product certification organization accredited for this purpose by ANSI.

INDIRECT ADDITIVES

11. **The City of Industry Waterworks** shall only use chemicals, materials, lubricants, or products that have been tested and certified as meeting the specifications of NSF/ANSI Standard 61 in the production, treatment or distribution of drinking water that will result in its contact with the drinking water, including process media, protection materials (i.e. coating, linings, liners), joining and sealing materials, pipe and related products, and mechanical devices used in treatment/transmission/distribution system, unless conditions listed in Section 64593, Title 22, CCR are met. This requirement shall be met under testing conducted by a product certification organization accredited for this purpose by ANSI.

ANNUAL REPORTS

12. **The City of Industry Waterworks** shall submit Annual Reports on the status and condition of the water system, as directed by the Division.

RECORDS

13. **The City of Industry Waterworks** shall keep complete records of any emergency and scheduled interruptions in water service. These records should include:
 - a) Location of the problem
 - b) Cause of the interruption
 - c) Date and approximate time of the problem
 - d) Precautions taken to minimize contamination of the supply and notification of affected users.

This permit supersedes all previous domestic water supply permits and permit amendments issued for this public water system, except for Permit Amendment 2017PA-SCHOOLS issued January 17, 2017, which is expressly incorporated by reference herein and which continues to be in full force and effect from the date of issuance. This permit shall remain in effect unless and until it is amended, revised, reissued, or declared to be null and void by the Division. This permit is non-

transferable. Should *the City of Industry Waterworks* undergo a change of ownership, the new owner must apply for and receive a new domestic water supply permit.

This permit shall be effective as of the date shown below.

**FOR THE DIVISION OF DRINKING WATER,
STATE WATER RESOURCES CONTROL BOARD**

11/15/2018
Date



**Dmitriy Ginzburg, P.E., District Engineer
Hollywood District**


Engineering Report

*For Consideration of a Revised Water Supply Permit for the
City of Industry Waterworks System
Serving portions of City of Industry, La Puente, Industry Hills and
an unincorporated area of Los Angeles County known as Avocado
Heights*

November 15, 2018

*Division of Drinking Water
State Water Resources Control Board*

Prepared by



*James Ko, P.E.
Associate Sanitary Engineer
Hollywood District*

Reviewed and Approved by



*Dmitriy Ginzburg, P.E., District Engineer
Hollywood District*

[Leave Blank Intentionally]

Table of Contents

1. INTRODUCTION.....	1
1.1 Brief Description of the System	1
1.2 Permit History	1
1.3 Enforcement History	2
2. SOURCES OF SUPPLY	2
2.1 Water Produced.....	2
2.2 Standby Sources, Emergency Supplemental Sources and Interconnections	2
2.3 Groundwater Sources.....	4
2.4 System Demand.....	4
3. TREATMENT FACILITIES.....	5
4. STORAGE FACILITIES.....	5
5. DISTRIBUTION SYSTEM.....	6
5.1 Pumping Facilities and Pressure Zones.....	6
5.2 Distribution/Transmission Pipelines/Asbestos Monitoring.....	7
6. WATER QUALITY MONITORING.....	8
6.1 Bacteriological Monitoring.....	8
6.2 Monitoring - Inorganic Chemicals	8
6.3 Monitoring - Nitrate	9
6.4 Monitoring - Nitrite	9
6.5 Monitoring - Perchlorate	9
6.6 Monitoring - Secondary Standard	9
6.7 Monitoring - Radiological	9
6.8 Monitoring - Volatile Organic Chemicals.....	9
6.9 Monitoring - Synthetic Organic Chemicals.....	9
6.10 Monitoring - Stage 2 Disinfection Byproducts Rule.....	9
6.11 Monitoring - Lead and Copper Rule (LCR)	10
7. RECYCLED WATER	11
8. OPERATION AND MAINTENANCE.....	11
8.1 Operator Certifications.....	11
8.2 Customer Complaints	12

8.3	Cross-Connection Program	12
8.4	Valve Exercising	12
8.5	Flushing Program	12
8.6	Emergency Response Plan	13
8.7	Consumer Confidence Report	13
8.8	Water Quality Emergency Notification Plan	13
8.9	Annual Report to the Drinking Water Program	13
9.	SYSTEM APPRAISAL.....	13
10.	CONCLUSIONS AND RECOMMENDATIONS	13

- Appendix A – Water System Map and Schematic
- Appendix B – Reservoirs Inspection Checklist
- Appendix C – Reservoir Inspection Report (from Dive/Corp, Inc)
- Appendix D – Reservoir Data Sheets
- Appendix E – Distribution Data Sheet
- Appendix F – Well Data Sheet
- Appendix G – Booster Station Data Sheets
- Appendix H – Cross-Connection Control Program Evaluation
- Appendix I – Water Supply Permit

1. INTRODUCTION

On January 11, 2018, the Division of Drinking Water (hereinafter Division) conducted an inspection of the City of Industry Waterworks System (herein after City). One item that was noted during the survey is that the City's current permit (issued on March 22, 2001) is outdated. This revised full permit will be prepared in conjunction with this sanitary survey in January 2018. The inspection was conducted by James Ko of the Division, with Mr. Roy Frausto, Engineering & Compliance Manager, and Mr. Cesar A. Ortiz, Water Treatment & Supply Supervisor. The last inspection of the City's water system was on January 13, 2015.

1.1 Brief Description of the System

The City's potable water system provides potable water supply to approximately 6,813 people through 1,934 service connections within the City itself and in adjacent unincorporated areas of Los Angeles County.

The service area is primarily zoned industrial and commercial with small pockets of residential areas. The City customers include a hotel, a golf course and the Industry Hills Equestrian Center. Other water purveyors serving other parts of the City are La Puente Valley County Water District (LPVCWD), Rowland Water District, Suburban Water Systems, and San Gabriel Valley Water Company (SGVWC).

The City system produces groundwater utilizing its only active groundwater source Well 5 and pumps the extracted groundwater to an offsite treatment facility, which is owned and operated by SGVWC. In exchange, the City receives water from SGVWC's distribution system through one of two permitted interconnections between the City and SGVWC.

The City system utilizes approximately 31.9 miles of pipelines, three water storage reservoirs that have a combined storage capacity of 7.5 million gallons (MG) serving three pressure zones, and five active booster stations having a combined total of fifteen pumps/boosters.

1.2 Permit History

A domestic water supply permit was initially issued to Cross Water Company on August 18, 1954. On March 22, 2001, the Division issued to the City a revised full permit (Permit No. 04-07-01P-001). The City of Industry is contracted with the La Puente Valley County Water District (LPVCWD) to maintain, operate, and monitor the water system since February 2004.

This permit supersedes all previous domestic water supply permits and permit amendments issued for this public water system, except for Permit Amendment 2017PA-SCHOOLS issued January 17, 2017, which is expressly incorporated by reference herein and which continues to be in full force and effect from the date of issuance. This permit shall remain in effect unless and until it is amended, revised, reissued, or declared to be null and void by the Division. This permit is non-transferable. Should the City of Industry Waterworks

System undergo a change of ownership, the new owner must apply for and receive a new domestic water supply permit.

1.3 Enforcement History

The City has not had any violations in the last ten years.

2. SOURCES OF SUPPLY

2.1 Water Produced

The City's groundwater sources consist of one (1) active, three (3) inactive, and one (1) abandoned water wells located near S. San Fidel Avenue in an unincorporated area of Los Angeles County known as Avocado Heights. Active Well No. 5 is the primary source of water supply with a capacity of 1,200 gallon per minute (gpm) which draws groundwater from the Main San Gabriel Ground Water Basin. The aquifer in the area where Well No. 5 draws water is contaminated with volatile organic compounds (VOC's), Perchlorate, and N-Nitrosodimethylamine (NDMA). The water from Well No. 5 is delivered to SGVWC for treatment at its Plant B5 and SGVWC then provides water from its distribution system to the City's Distribution System through two major interconnections between the two systems. Table 1 below lists the City's only active groundwater source.

Table 1 – Active Groundwater Source

Sources	PS Code	Status	Capacity (gpm)
Well No. 5	1910029-007	Active	1,200

2.2 Standby Sources, Emergency Supplemental Sources, and Interconnections

The City maintains 9 interconnections with surrounding water purveyors. The City can receive water from 7 connections; however, it primarily receives nearly all its water supply through the interconnection with SGVWC located at the Lomas Reservoir. The other interconnections provide either emergency backup supply or supplemental supply to the City and provide the surrounding purveyors with either emergency backup supply or supplemental supply from the City.

Table 2 below lists the locations and known capacities of the interconnections to and from the City. When the City's current water supply from SGVWC is unavailable, the City can receive water from adjacent water purveyors via these interconnections.

Table 2 – City Interconnections

No.	Connection	Source	Size	Flow Direction	Capacity (gpm)	Status
1	SGVWC Lomitas Reservoirs	GW	12"	SGVWC to City Zone 1	2,000	Active
2	SGVWC Workman Mill	GW	10"	SGVWC to City Zone 1	2,000	Active
3	SGVWC Salt Lake	GW	2"	SGVWC to City Zone 1	50	Active
4	LPVCWD Industry Hill PS 1 (Hill St.)	GW	16"	LPVCWD to City Zone 1	2,000	Emergency
5	LPVCWD Valley Blvd & Proctor Ave.	GW	14"	LPVCWD to City Zone 1	2,000	Emergency
6	LPVCWD Industry Hills PS 3	GW	12"	LPVCWD to Industry Hills	1,200	Emergency
7	LPVCWD Industry Hills Reservoir	GW	8"	Bi-Directional (Industry Hills)	400 to City	Active
8	LPVCWD Holguin Place	GW	4"	City to LPVCWD	195	Active
9	LPVCWD San Jose Ave & Holguin Place	GW	12"	City to LPVCWD	2,000	Emergency
Total System Active Source Capacity					11,845	MDD = 2.75 MGD (the highest maximum day demand over the past 10 years) 4 x PHD = (MDD/24hr x 1.5 = 0.69 MG

Although water produced from Well No. 5 is about 1,200 gpm, the City can receive up to 4,050 gpm from SGVWC'S interconnections.

2.3 Groundwater Sources

The City owns five water wells, which are all located at the San Fidel Wells Yard. Out of five wells, only one well (Well No. 5) is active, one well (Well No. 1) is abandoned, one well (Well No. 2) is inactive, and two wells (Well No. 3 and 4) are inactive due to aquifer contamination. Wells No. 3, 4 and 5 are surface sealed, and are located within a 100-year flood zone in a dry riverbed of San Gabriel River and are located near a residential neighborhood adjacent to freeway 605.

Well No. 5 is located 50 feet north of Well No 4 in the same yard and was drilled to a depth of 980 feet in 1984. The wellhead and its equipment are housed within a secured building. The well is equipped with the 200-hp electric motor and “Flowserve” lubricated vertical turbine water pump rated 1,200 gpm. Well pumps 3, 4, and 5 sit on a 6-inch-high surface sealed concrete bases and equipped with the appropriate appurtenances. Well No 5 pumps into a dedicated transmission line that runs from the City’s well field to SGVWC's B-5 treatment facility.

2.4 System Demand

The City serves potable water within the City of Industry and La Puente and unincorporated portions of Los Angeles County (Avocado Heights Area). Land use within the portion of service area served by the City is primarily commercial and industrial. Land use within the City’s service area in unincorporated portions of Los Angeles County is primarily residential.

From 2010 to 2017, the average water usage was approximately 1,351 AFY. For the years 2010 through 2017, the annual water use data is shown in Table 3 below.

Table 3 – Current Water Demand

Year	Water Use (AFY)	Water Use (gpm)
2010	1,382.21	856.35
2011	1,321.04	818.45
2012	1,401.54	868.32
2013	1,352.56	837.98
2014	1,296.64	803.33
2015	1,313.63	813.86
2016	1,392.38	862.40
2017	1,345.33	833.3
Average	1,350.67	836.7

The City’s Maximum Day Demand (MDD) per Section 64554(b)(1), Title 22 is 2.75 MGD as calculated in the table above. The total production capacity of the City’s active wells and purchased sources is 17.1 MGD. The estimated Peak Hourly Demand (PHD) calculated using the method specified in Section 64554(b)(1) is 0.172 MGH. To be able to meet four

hours of PHD, the City's water system needs source capacity, storage capacity, and/or emergency source connections capacity to exceed $0.172 \text{ MGH} \times 4 = 0.69 \text{ MG}$. The total source capacity (17.1 MGD) and storage capacity (7.5 MG – see the table 4 in Section 4 below) independently satisfy the requirement. Therefore, the City water system has sufficient water to meet the MDD and four hours of PHD.

3. TREATMENT FACILITIES

As part of the EPA mandated Baldwin Park Operable Unit (BPOU) cleanup, a treatment facility was constructed at SGVWC's Plant B5 in 2008 to treat water from the City's Well No. 5 and SGVWC wells for VOCs, Perchlorate, NDMA, and 1,4-Dioxane. VOCs are removed from the water by a liquid phase granular activated carbon (LGAC) system. The Perchlorate is removed by a single pass ion exchange system. NDMA is destroyed by an ultraviolet (UV) and hydrogen peroxide advanced oxidation process (AOP) system. Hydrogen peroxide is added prior to the UV treatment system to assist in the destruction of 1,4-Dioxane and for enhanced destruction of NDMA.

SGVWC's Plant B5 is located at 209 Perez Place, east of San Gabriel River Freeway 605 and north of Valley Boulevard in the City of Industry. It is owned and operated by SGVWC, a private water company regulated by the California Public Utilities Commission. The current flow capacity of the treatment plant is 7,800 gpm. The BPOU agreement guarantees the City 1,200 gpm of treatment capacity within the Plant B5 Treatment Facility for treating the amount of water sent to the treatment facility from Well No. 5. This treated groundwater is the primary source of potable water for the City.

Sodium Hypochlorite is injected into the treated water line and passed into the onsite reservoirs. Required CT value is achieved in storage reservoirs. Water from the reservoirs is pumped into the SGVWC's Distribution system via onsite Booster Pumps.

The City receives disinfected water from one of the interconnections between SGVWC and the City. The City monitors free chlorine residuals daily from selected sites in the water system.

4. STORAGE FACILITIES

The City has three potable water storage reservoirs, and each reservoir has a storage capacity of 2.5 MG as listed in Table 4 below.

Table 4 – Reservoir Summary

Name	Capacity (MG)	Base Elevation (ft. AMSL)	Full Elevation	Last inspected/cleaned	Year Completed	Last Relined and Recoated
Lomitas	2.5	392	424	8/2017	1986	2013
Industry Hills East	2.5	743	775	8/2017	1978	2011
Industry Hills West	2.5	743	775	8/2017	1978	2011
Total System Storage Capacity	7.5					

The City's Zone 1 is pressurized from the interconnections from SGWVC and the Booster Pumps located at the Lomitas Reservoirs. The Lomitas 2.5 MG reservoir serves as a storage facility for Zone 1 and is located at the City Yard on Lomitas Avenue. The Lomitas Reservoir was constructed in 1986 and is of steel construction, including sidewalls, floor and roofs. A five-thousand-gallon hydro-pneumatic tank is located adjacent to the Lomitas Reservoir. Emergency diesel-powered generator and 3 booster pumps were installed next to the Lomitas Reservoir in 1999.

The City's Industry Hills Zone receives water from the Lomitas Reservoir Booster Pumps and two Industry Hills Pump Stations. The other two reservoirs are in the Industry Hills development above the City of La Puente. Both Industry Hills Reservoirs were constructed in 1978 and are of steel construction, including sidewalls, floor and roof.

Dive/Corr, Inc. inspected the three reservoirs in August 2017, and the City has completed the Dive's recommendations. The City has scheduled and cleaned its reservoirs at least once every five years.

Overall, the City's three reservoirs are in good condition.

5. DISTRIBUTION SYSTEM

5.1 Pumping Facilities and Pressure Zones

The City has five (5) active booster pumping stations. Each station has three (3) booster pumps with varying horse-powers, design flows, and design heads.

Currently, there are two (2) main zones and three (3) sub-zones in the City's distribution system:

- Pressure Zone 1 is served primarily by the Lomasitas Booster Station, which is supplied by the Lomasitas Reservoir. SGVWC interconnections can also pressurize Zone 1 if the Lomasitas Booster Station is out of service or is unable to meet the supply demand. If the Lomasitas Reservoir and Booster Pump Station are out of service, the interconnection with LPVCWD's Zone 1 can temporarily supply the entire City Zone 1 via gravity feed.
- Salt Lake Sub-Zone is served by an interconnection from SGVWC.
- Industry Hills Zone is served by the Industry Hills Pump Station 2 located east of Industry Hills Pump Station 1 and the Industry Hills Pump Station 1 located south of Temple Avenue. Pump Station 1 feeds the (Lower Zone) industry hills zone and/or pumps water towards the Wet Well located near Industry Hills Pump Station 2. From there, the water is pumped through Industry Hills Pump Station 2 to the Industry Hills Tanks and/or to the Pump Station 2 Sub-Zone (Upper Zone).
- Pump Station 2 Sub-Zone (Upper Zone) serves a portion of the Industry Hills equestrian area.
- Lake Loop Subzone is served by Lake Loop Booster Station located north of BV Handorf Drive near the Dwight D. Eisenhower Golf Course.

5.2 Distribution/Transmission Pipelines/Asbestos Monitoring

The distribution system for the City consists of approximately 34.4 miles (181,631 ft.) of water pipeline, ranging in size from 1-inch to 20-inch. Asbestos Cement Pipe is the most common pipeline material within the system. The City also contains steel, cement mortar lined and coated steel, ductile iron and polyvinyl chloride (PVC). Asbestos cement pipe is no longer readily available due to environmental hazards associated with manufacturing and installation. For that reason, when an asbestos pipeline replacement is needed within the system, it will be replaced with PVC or ductile iron pipe. Table 5 below provides a breakdown of the existing pipelines by diameter and material.

Table 5 – Pipeline Summary

Size (in)	AC (ft)	DIP (ft)	PVC (ft)	STL (ft)	Total (ft)
1	82	-	280	276	639
2	1,456	-	69	11,050	12,574
2.5	175	-	-	886	1,062
3	-	-	-	1,829	1,829
4	10,015	-	1,589	1,647	13,252
6	25,185	181	660	6,323	32,348
8	21,069	3,083	1,329	660	26,143
10	7,884	886	-	515	9,285
12	19,353	1,409	-	5,211	25,972

Size (in)	AC (ft)	DIP (ft)	PVC (ft)	STL (ft)	Total (ft)
14	3,979	7,275	-	-	11,253
16	42,958	1,849	-	1,136	45,943
18	500	537	-	-	1,037
20	78	-	-	216	294
Totals	132,734	15,220	3,927	29,749	181,630

The City monitored for Asbestos in its distribution system on September 27, 2013. The result was a non-detect (ND). Therefore, the City's has completed the distribution system asbestos monitoring for the third compliance cycle (2011-2019).

During the site inspection, the booster pumps appeared to be in good condition. There were no signs of wear or of any improper connections.

6. WATER QUALITY MONITORING

6.1 Monitoring Bacteriological

Per the Total Coliform Rule (TCR), the City must collect two total coliform (TC) samples weekly from the distribution system. The City currently collects 20 TC samples during four-week months and 25 samples during five-week months. This works out to be 5 weekly samples, which is more than what is required. The City must submit the TC distribution system results monthly to the Division by the 10th of the following month. In the past 10 years, the City has been in compliance with the TCR MCL.

The City must collect residual disinfectant samples from the same locations and the same time that it collects the TC distribution system samples. The monthly average of residual disinfectant samples has been below the maximum residual disinfectant level (MRDL) of 4.0 mg/L for free chlorine.

The City last updated its Bacteriological Sample Siting Plan (BSSP) in December 2016. The City must update its BSSP every ten years and at any time the BSSP does not represent monitoring in the distribution system. If the City has a positive TC sample in the distribution system, then it must follow its Groundwater Rule (GWR) monitoring plan to notify SGVWC and LPVCWD of any positive TC samples in the distribution system.

6.2 Monitoring – Inorganic Chemicals

The City does not collect samples for inorganic chemicals, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.3 Monitoring – Nitrate

The City does not collect samples for nitrate, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.4 Monitoring – Nitrite

The City does not collect samples for nitrite, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.5 Monitoring – Perchlorate

The City does not collect samples for perchlorate, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.6 Monitoring – Secondary Standards

The City does not collect samples for secondary standards, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.7 Monitoring – Radiological

The City does not collect samples for radiological chemicals, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.8 Monitoring – Volatile Organic Chemicals

The City does not collect samples for volatile organic chemicals, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.9 Monitoring – Synthetic Organic Chemicals

The City does not collect samples for synthetic organic chemicals, because Well No 5 Water is treated by SGVWC's B-5 treatment facility. All the samples are collected and reported by SGVWC.

6.10 Monitoring – Stage 2 Disinfection Byproducts Rule

Under the Stage 2 DBPR, the City has been classified as a Schedule 1 water system. The City began complying with the Stage 2 DBPR monitoring and reporting requirements in the third quarter of 2012. The Stage 2 DBPR monitoring consists of sample collection at two sites that are monitored annually. Between the years of 2015 to 2017, the locational running

annual average (LRAA) at the two sample sites range from 0.64 – 16.00 ppb for total trihalomethanes (TTHM) and 0.00 – 1.50 for five haloacetic acids (HAA5). The three year's TTHM and HAA5 summary sheets are attached in the end of this report. The City is in comply with the Stage 2 DBPR monitoring and reporting requirements.

6.11 Monitoring – Lead and Copper Rule (LCR)

The City is a medium-size water system for LCR because it serves greater than 3,300 and less than or equal to 50,000 persons. The City is required to collect 20 lead and copper samples from the distribution system. The last LCR monitoring round was conducted in July of 2016. Out of the 23 samples collected, the 90th percentiles for lead and copper were 0.0031 mg/L and 0.580 mg/L, respectively, which are below the lead and copper action levels. According to the LCR, the City is eligible to continue triennial monitoring. The next monitoring round is required in 2019 during the warmer months of June, July, August, or September.

Table 6: Lead and Copper Monitoring Results

Frequency	Date	Number of Samples	90th Percentile Results	
			Lead, ug/L	Copper, ug/L
Semi-Annual	January 1993	40	8	657
Semi-Annual	July 1993	40	< 5	711
Triennial	August 1998	40	< 5	179
Triennial	September 2000	20	< 5	657
Triennial	October 2004	21	< 5	370
Triennial	October 2007	20	< 5	150
Triennial	September 2010	20	< 5	150
Triennial	July 2013	20	< 5	440
Triennial	July 2016	23	< 5	580

Frequency	Date	Number of Samples	90th Percentile Results	
			Lead, ug/L	Copper, ug/L
Triennial	July 2019			

7. RECYCLED WATER

The Industry Hills Civic Recreation-Conservation Area (Equestrian Center) and golf courses are irrigated with recycled water from Los Angeles County Sanitation District-San Jose Plant. The San Jose Plant effluent feeds a 36-inch line through Pumping Plant No. 1 to two (2) 2.1 MG reservoirs. Water from the 2.1 MG reservoirs then goes to Pumping Plant No. 2 which pumps the recycled water through a 16-inch line to a series of lakes and distributed to the Equestrian Center's irrigation system. Proper reduced pressure principle backflow prevention devices are installed on the meters. The recycled water system is physically separated from the domestic water system. Two (2) miles of a 16-inch pipe is in place within the City of Industry boundary.

Each new site where recycled water is approved by the Los Angeles County Health Department, Cross Connection Control Section. The site is also subject to inspection by the Los Angeles County Health Department prior to being placed into service.

8. OPERATIONS AND MAINTENANCE

8.1 Operator Certifications

The City of Industry is contracted with the LPVCWD to operate the City. Currently, the LPVCWD has ten certified treatment and distribution operators operating the system. The water system is not required to have treatment operators, as pursuant to Title 22, Chapter 13, Article 2, Section 63770 of the California Code of Regulations, certified distribution system operators may determine chemical dosage rates for distribution residual maintenance if needed. According to Section 64413.3 of the Operator Certification Regulations, Title 22, CCR, the City is classified as a D2 system for distribution system. Distribution system classification is based on population served and complexity of system. The chief and shift operator(s) for the distribution facilities shall have, at minimum, D2 and D1 certification, respectively. An updated list of certified operators currently employed by the City along with their operator grade information was provided in the 2017 Electric Annual Reporting System submitted to the Division. The City has adequate number of certified water distribution operators with the proper levels of certifications.

8.2 Customer Complaints

The City's administrative staff receives the customer complaints and routes the information to the operators. The operators respond to the customers through a field visit. The City keeps records of all customer complaint incidents on file in its office.

8.3 Cross-Connection Control Program

The City's existing cross connection program is adequate, and all backflow prevention assemblies are tested on an annual basis. Currently, Mr. Cesar A. Ortiz is the City's cross connection coordinator with a cross connection specialist certificate obtained from AWWA after completing Cross Connection Control Specialist and Backflow Tester courses in June 2010. A cross connection control program evaluation form was completed and is included as an attachment to this Report.

The LPVCWD's Engineering & Compliance Manager notifies its own Treatment & Supply Supervisor (Mr. Cesar Ortiz) whenever a new development occurs within the service area. The Treatment & Supply Supervisor then conducts a cross connection inspection of the new development and completes a cross connection control inspection report. In his inspection report, Mr. Cesar A. Ortiz determines if a backflow prevention assembly is required at the site.

The City requires that all backflow prevention assemblies be tested annually by their site owners. The City mails testing notices to the site owners. Each site owner is responsible for testing his assembly and sending the testing reports to the City.

If the site owner does not test his assembly, then the City will shut off the water to the site. Reduced pressure (RP) and double check (DC) assemblies are the types of assemblies being used in the water system. Most of the assemblies currently being used are RP assemblies. All assemblies are tested every year.

8.4 Valve Exercising

The City has a valve maintenance program, dated in January 2017, on file with the Division. The program outlines the objectives of the program including determination of the number of valves, their locations, and the type of valves, etc. The program also sets policy ensuring timely repair of damaged valves along with procedures for properly exercising valves. Per program, valves should be inspected and exercised every four (4) years. Valves that have been determined to be critical should be exercised every 4 years and inspected annually.

8.5 Flushing Program

The main goals of the flushing program are to maintain regulatory compliance, minimize customer complaints, and maintain disinfectant residual throughout the system while minimizing the quantity of water used for flushing. Currently, the City has 64 dead-end

water mains and hydrants that are flushed on an annual basis (Note: During times of low groundwater basin levels and/or severe drought conditions, the dead-end flushing program will be performed on an as needed basis).

The City keeps detailed records of all flushing activities on a "Flushing Schedule Worksheet." When the City performs a flushing activity, some of the pertinent data that is recorded on the worksheet includes: date of activity, name of operator, location of activity, color of water when flushed, time to complete flushing, and type and size of equipment that was flushed. A regular flushing routine ensures that water does not become stagnant in the distribution system, avoiding the potential for any bacteriological growth to occur, as well as nitrification, or other water quality problems which might lead to unpleasant odor, taste, or appearance. Flushing records are satisfactory.

8.6 Emergency Response Plan

A copy of the Emergency Response Plan (ERP) is on file with the Division. The City's ERP was revised on December 28, 2016.

8.7 Consumer Confidence Report

The Division has the City's 2017 Consumer Confidence Report (CCR) on file.

8.8 Water Quality Emergency Notification Plan

The Division has the City's 2017 Water Quality Emergency Notification Plan (WQENP) on file. The WQENP is due every year by April 30.

8.9 Annual Report to the Drinking Water Program

The Division has the City's 2017 Annual Report to the Drinking Water Program (ARDWP) on file. The ARDWP is due every year by April 30.

9. SYSTEM APPRAISAL

The overall operations and facilities of the City are adequate. The City's system is generally in good condition. The sites are well kept, and all equipment is in decent condition and maintained on a regular basis.

10. CONCLUSIONS AND RECOMMENDATIONS

The Division has determined that the City is capable of providing a safe, wholesome, and potable water supply meeting all applicable State Drinking Water Standards when operated

in compliance with this permit. Issuance of the revised full domestic water supply permit by the Division to the City is recommended subject to the following conditions:

GENERAL

1. The City of Industry Waterworks shall comply with all state laws applicable to public water systems and any regulations, standards, or orders adopted thereunder.
2. All water supplied by the City of Industry Waterworks for domestic purposes shall meet all Maximum Contaminant Levels (MCLs) established by the Division of Drinking Water. If the water quality does not comply with the California Drinking Water Standards, treatment shall be provided to meet standards.
3. The only sources approved for domestic water supply are the following:

Table 1: Active Groundwater Source

Sources	PS Code	Status	Capacity (gpm)
Well No. 5	1910029-007	Active	1,200

Table 2: Purchased Water Sources

No.	Connection	Source	Size	Flow Direction	Capacity (gpm)	Status
1	SGVWC Lomas Reservoirs	GW	12"	SGVWC to City Zone 1	2,000	Active
2	SGVWC Workman Mill	GW	10"	SGVWC to City Zone 1	2,000	Active
3	SGVWC Salt Lake	GW	2"	SGVWC to City Zone 1	50	Active
4	LPVCWD Industry Hill PS 1 (Hill St.)	GW	16"	LPVCWD to City Zone 1	2,000	Emergency
5	LPVCWD Valley Blvd & Proctor Ave.	GW	14"	LPVCWD to City Zone 1	2,000	Emergency
6	LPVCWD Industry Hills PS 3	GW	12"	LPVCWD to Industry Hills	1,200	Emergency
7	LPVCWD Industry Hills Reservoir	GW	8"	Bi-Directional (Industry Hills)	400 to City	Active

No.	Connection	Source	Size	Flow Direction	Capacity (gpm)	Status
8	LPVCWD Holguin Place	GW	4"	City to LPVCWD	195	Active
9	LPVCWD San Jose Ave & Holguin Place	GW	12"	City to LPVCWD	2,000	Emergency

4. There are no approved treatment processes in the City of Industry Waterworks System's system.
5. No changes, additions, or modifications shall be made to the sources or treatment processes outlined in Provisions 3 through 4 unless an amended water permit has first been obtained from the Division.

WATER QUALITY

6. The City of Industry Waterworks shall ensure that monitoring of all active sources is conducted in accordance with the vulnerability assessment issued by the Division of Drinking Water.

OPERATOR CERTIFICATIONS

7. The City of Industry Waterworks water system is not required to have treatment operators, as pursuant to Title 22, Chapter 13, Article 2, Section 63770 of the California Code of Regulations, certified distribution system operators may determine chemical dosage rates for distribution residual maintenance if needed.
8. The City of Industry Waterworks distribution system shall be operated by personnel who have been certified in accordance with Chapter 13, Title 22, CCR, Operator Certification Regulations. The chief and shift operator(s) for the distribution facilities shall have, at minimum, D2 and D1 certification, respectively.

CROSS-CONNECTION CONTROL PROGRAM

9. The City of Industry Waterworks shall comply with Title 17, CCR, to prevent the water system from being contaminated by possible cross-connections. The City of Industry Waterworks shall maintain a program for the protection of the domestic water system against backflow from premises having dual or unsafe water systems in accordance with Title 17. All backflow preventers shall be tested at least annually.

DIRECT ADDITIVES

10. The City of Industry Waterworks shall only use additives that have been tested and certified as meeting the specifications of NSF International/American National Standard Institute (NSF/ANSI) Standard 60. This requirement shall be met under testing conducted by a product certification organization accredited for this purpose by ANSI.

INDIRECT ADDITIVES

11. The City of Industry Waterworks shall only use chemicals, materials, lubricants, or products that have been tested and certified as meeting the specifications of NSF/ANSI Standard 61 in the production, treatment or distribution of drinking water that will result in its contact with the drinking water, including process media, protection materials (i.e. coating, linings, liners), joining and sealing materials, pipe and related products, and mechanical devices used in treatment/transmission/distribution system, unless conditions listed in Section 64593, Title 22, CCR are met. This requirement shall be met under testing conducted by a product certification organization accredited for this purpose by ANSI.

ANNUAL REPORTS


12. The City of Industry Waterworks shall submit Annual Reports on the status and condition of the water system, as directed by the Division.

RECORDS

13. The City of Industry Waterworks shall keep complete records of any emergency and scheduled interruptions in water service. These records should include:
 - a) Location of the problem
 - b) Cause of the interruption
 - c) Date and approximate time of the problem
 - d) Precautions taken to minimize contamination of the supply and notification of affected users.

APPENDIX A

Water System Map and Schematic



INDUSTRY HILLS ZONE (UPPER & LOWER) - 775 FT. HGL ZONE

ZONE 1 - 495 FT. HGL ZONE

APPROVED BY THE BOARD OF DIRECTORS OF
LA PUENTE VALLEY COUNTY WATER DISTRICT
6/2/17
DATE
SERG GALINDO
GENERAL MANAGER

DRAWN BY
ROY FALUSTO
APPROVED BY
SERG GALINDO

CITY OF INDUSTRY WATERWORKS SYSTEM

HYDRAULIC FLOW DIAGRAM

APPENDIX B

Reservoirs Inspection Checklist

APPENDIX C

Reservoir Inspection Report (from Dive/Corp, Inc)

DIVE / CORR, INC.

Industrial Photography & Inspection Services

P. O. BOX 30427 • LONG BEACH, CA 90853 • OFFICE (562) 439-8287 • FAX (562) 438-7151

TANK INSPECTION REPORT

AGENCY	La Puente CWD	DATE INSPECTED	8/03/17
SUPERVISOR	Mr. Greg Galindo	TANK NAME	West
SIZE	2.50 MG	HATCH	East
INSPECTOR	Dan Gross	DATE BUILT	1978
LADDER	Yes/Int-Yes/Ext	TENDER	F Echandi
BRIEF	General Survey	CP	Yes/Sac
		LAST INSPECTED	NA

CITY OF INDUSTRY

WEST TANK

THE FOLLOWING PHOTOGRAPHS CORRESPOND TO NUMBERS VIEWED AT THE BOTTOM OF THE ALBUM PAGES WHEN THE ALBUM IS VIEWED IN CENTERFOLD MODE:

15-16) City of Industry - West Tank. This is an above ground welded steel reservoir, four plate courses plus a knuckle course tall. The lowest course is referred to as course #1.

There are two tanks on this site. The West Reservoir is the tank with no access stairway and is farthest from the site access gate.

17-18) The tank nameplate is above the round manway shown in photograph (#19).

FABRICATOR	-	AMERICAN BRIDGE
CONTRACT #	-	K9310
YEAR BUILT	-	1978
HEIGHT	-	36'5"
WIDTH	-	110'
SIZE	-	2.5 MG

DIVE / CORR, INC.

19-38) The exterior wall coating is in good condition. No notable defects were sighted.

This tank has two round manways (#19,35). A transfer pipe (#23) is present. There are flexible couples.

The overflow exits through course #1 (#21). The end has a duckbill.

The exterior target is properly indicating water level (#29). The tank had 31' at the time of inspection.

The tank has a concrete retaining ring. No significant defects were sighted. This tank does not have anchor bolts.

39-76) The exterior roof coating is in good condition. No notable defects were sighted.

The vent hood (#45-50) is secure. Rust is evident on the screen.

A sacrificial anode Cathodic Protection System has been added. Hand hole covers are in good condition. Of note is that the holes are 6" in diameter. The NACE (National Association of Corrosion Engineers) standard is a 5" hole. Grommets were added at the end of the inspection (#61-64).

The roof access hatch (#73) was found properly locked. For the purposes of this report, the hatch will be referred to as being on the West side.

This tank has both handrail and safety cables. These appear to be in good condition.

77-86) The above water portion of the interior access ladder and telemetry pipe is secure and the coating is in good condition.

DIVE / CORR, INC.

87-96) The above water portion of the overflow funnel appears securely attached and in overall good condition. The adjacent shell and roof coating are in good condition.

97-122) There are four plate courses plus a knuckle course. The top 5' are above water. The above water walls are in good condition. No notable defects were sighted.

Beam ends are bolted to welded knuckle braces. All beams appear properly coated, upright and securely attached.

There are two fasteners per beam. Fasteners are in good condition.

The float (#107-112) is properly connected to the two guide wires as well as the traveling wire. The pan appears to move properly with a change in elevation.

123-206) The roof underside coating is in good condition. No notable defects were sighted. Patches are in good condition (#167,173).

All wiring for the Impressed Current Cathodic Protection System appears to be intact. No loose or fallen strings were identified. These were not pull tested. All anode wires are connected to the roof (#127).

All beams appear upright and securely attached. No gross bending or twisting was sighted.

The columns appear upright and stable. No indications of movement were observed. The above water column coating is in good condition.

207-216) The below water portion of the internal access ladder appears securely attached and in good condition.

The ladder has a safety climb rail. This also appears securely attached and in good condition.

DIVE / CORR, INC.

217-218) The guide wires are securely attached and in good condition. Sediment seen here is considered typical and barely covers the floor.

219-230) A telemetry pipe is adjacent to the internal access ladder. The coating is in good condition. Of note is that there are two slots cut into the base (#207).

Small coating blisters are seen in very sparse numbers along the cut-out edge (#225-230) on both sides. Half of the blister caps are broken. Rust is not associated with this condition.

A transducer is not evident internally.

231-234) The drain exits through the floor. The opening is clear.

235-270) The floor coating is in good overall condition. Many patches are seen. Patches are in good condition.

Sediment is null and barely covers the floor. No measurable deposits were found. No foreign debris from vandalism was sighted.

This tank has sacrificial anodes. The anodes ground directly to the roof. There is no header cable or test box.

As the anodes decay, slough piles develop below (#253). The slough pile depths vary from moderate (#263,265,267) to very slight (#257).

271-274) The inlet/outlet is common and enters though course #1. The coating is in good condition. The adjacent shell coating is typical and in good condition.

275-292) The overflow pipe is internal and exits through course #1. The pipe coating is in good condition. No notable defects were sighted.

DIVE / CORR, INC.

Wall and floor braces also appear to be in good condition. No corrosion was sighted.

- 293-304) There are two round manways. The plates in both cases are in good condition.

Corrosion at support hardware is minimal (#297).

- 305-344) There are four plate courses plus a knuckle course. The top 5' feet was above water and has been previously described as being in good condition.

The below water coating is in good condition. Patches are found scattered over the surface. These appear to be in good condition. Rust tubercles are rare and small where found (#309). No notable corrosion was seen.

- 345-372) The below water portion of the column pole coating is in good condition. No notable defects were sighted.

The bases appear stable and the coating is in good condition.

- 373-388) This tank has sacrificial anodes. In all cases, decomposition is very slight and all anodes are in near new condition.

For reference, several of the anodes show no sign of decay (#379,387).

DIVE / CORR, INC.

SUMMARY WEST TANK

EXTERIOR WALLS	-	Good
EXTERIOR ROOF	-	Good
VENT	-	Securely attached.
Screening	-	Rusting
HATCH	-	Securely locked - East side.
Handrail	-	Good
Safety Cables	-	Two
INTERIOR ROOF	-	Good
ABOVE WALLS	-	Top 5' - good
BELOW WALLS	-	Good
FLOOR	-	Good
SEDIMENT	-	Most of the floor is either bare or near bare. No measurable deposits. No foreign debris from vandalism was found.
STAIRS - Ext	-	None
Vandal Guard	-	
LADDER - Int	-	Securely attached - good condition
SAFETY RAIL	-	Good
FLOAT	-	Good
Target	-	Indicator properly riding on the target board at this elevation.
Guide Wires	-	Good
OVERFLOW	-	Interior pipe - good
MANWAY #1	-	Good

DIVE / CORR, INC.

MANWAY #2 - Good

DRAIN - Clear - exits through the floor.

COLUMNS - Good

INLET - Clear - good coating condition.

Flex Couple - Yes

OUTLET - Same as the inlet.

TELEMETRY PIPE - Good - sparse number of coating blisters by the floor cut-out. No related corrosion.

CATHODIC SYST

Hand Hole Covers Yes - good condition

Grommets Yes - added at the end of the inspection

Anodes Near new condition

Potentials taken by this inspector using a portable copper copper sulfate reference cell.

TOP -1.187 mVolts




MID -1.190 mVolts





BOT -1.223 mVolts





DIVE / CORR, INC.





RECOMMENDATIONS




- 1) Externally, the tank coating is in good condition and no action is recommended.
- 2) Internally, the coating is also in good condition. No corrosion issues are observed at this time.
- 3) This tank has an internal telemetry pipe. There are two small openings at the base and water exchange appears poor. In addition, the sacrificial anodes cannot protect all of the interior surfaces. Consider removing this pipe at the next maintenance cycle.
- 4) The roof vent screen is rusting. Anticipate that this will need changing in one year.

















DIVE / CORR, INC.

Industrial Photography & Inspection Services

P. O. BOX 30427 • LONG BEACH, CA 90853 • OFFICE (562) 439-8287 • FAX (562) 438-7151

TANK INSPECTION REPORT

AGENCY	La Puente CWD	DATE INSPECTED	8/03/17
SUPERVISOR	Mr. Greg Galindo	TANK NAME	Alamitas
SIZE	2.50 MG	HATCH	West
DIVER	Dan Gross	DATE BUILT	1986
LADDER	Yes/Int-Yes/Ext	TENDER	F Echandi
BRIEF	General Survey	CP	Yes / Sac
		LAST INSPECTED	NA

CITY OF INDUSTRY

LAS ALAMITAS TANK

THE FOLLOWING PHOTOGRAPHS CORRESPOND TO NUMBERS VIEWED AT THE BOTTOM OF THE ALBUM PAGES WHEN THE ALBUM IS VIEWED IN CENTERFOLD MODE:

15-16) Las Alamitas Tank. This is an all steel, above ground reservoir, three plate courses plus a knuckle course tall. The lowest course is referred to as course #1. This is the only tank on this site.

17-18) The tank nameplate is above the round manway shown in photograph (#19).

FABRICATOR	-	PITTSBURGH-DES MOINES
CONTRACT #	-	56517
YEAR BUILT	-	1986
HEIGHT	-	29'
WIDTH	-	120'
SIZE	-	2.5 MG

19-48) The exterior wall coating is in good condition. No notable defects were sighted.

This tank has two round manways (#19,43) and a small clean-out door (#43).

DIVE / CORR, INC.

The blue pipe does not have a visible flexible couple (#29). Piping on the East side of the tank does have a flexible couple (#37).

The external access ladder was found properly locked. No evidence of vandalism was seen either externally or internally.

The system originally connected to the Cathodic Protection box (#23-26) has been removed. New sacrificial anodes have been installed. These are ground directly to the roof and not connected to a control/test box.

The New CP system was last inspected on 6/22/2016 (#27) by Corrpro. Potentials shown in 2016 were very close to the potentials found by this inspector using a remote Copper Copper Sulfate reference cell.

The overflow exits through the floor as does the drain.

The exterior target is properly indicating water level (#31). The tank had 26' at the time of inspection.

The tank has a concrete retaining ring. No significant defects were sighted. This tank does not have anchor bolts.

49-80) The exterior roof coating is in good condition. No notable defects were sighted.

There are two vent hoods (#49). Both appear securely attached.

A new sacrificial anode Cathodic Protection System has been added. Hand hole covers (#57) are in good condition. Rust was seen on the coating where the covers were removed (#59-62). The coating attached to the cover gasket (#63). Grommets were added at the end of the inspection (#61-64).

DIVE / CORR, INC.

The roof access hatch (#79) was found properly locked. For the purposes of this report, the hatch will be referred to as being on the West side.

This tank has both handrail and safety cables. These appear to be in good condition.

81-92) The above water portion of the interior access ladder is secure and the coating is in good condition.

Close examination of photographs (#85-88,89-92) shows rust on the inside faces of the two knuckle braces on either side of the internal access ladder.

93-100) The above water portion of the overflow pipe appears securely attached and in overall good condition. The shroud cover appears stable and is bolted in place. There is a very slight line of rust along the shroud edge (#97).

101-104) The float is properly connected to the traveling wire as well as the two guide wires. Both guide wires are connected at the roof and the floor. The float appears to move properly with a change in elevation.

105-132) There are three plate courses plus a knuckle course. The top 5' are above water. The above water walls are in good condition.

Beam ends are bolted to welded knuckle braces. All beams appear properly coated, upright and securely attached. As previously mentioned, light rust staining is seen on two of the knuckle braces by the internal access ladder.

There are two fasteners per beam. Fasteners are in good condition.

Anodes are attached directly to the roof underside. Appearances are that the covers were leaking (#125-128). Grommets were added to provide a better seal.

DIVE / CORR, INC.

133-192) The roof underside coating is in good condition. No notable defects were sighted.

All wiring for the Impressed Current Cathodic Protection System appears to be intact. No loose or fallen strings were identified. These were not pull tested. All anode wires are connected to the roof (#139).

All beams appear upright and securely attached. No gross bending or twisting was sighted.

The columns appear upright and stable. No indications of movement were observed. The above water column coating is in good condition.

193-202) The below water portion of the internal access ladder appears securely attached and in good condition.

203-204) The guide wires are securely attached and in good condition. Sediment seen here is considered typical.

205-252) The floor coating is in good overall condition. There are an estimated 10 very small rust tubercles scattered over the surface (#207-214 / the yellow ruler shown in all photographs in this report is 6" long by 1" wide). Pitting was less than 1/16" deep in all cases.

Sediment is null and barely covers the floor. No measurable deposits were found. No foreign debris from vandalism was sighted.

This tank has sacrificial anodes. The anodes ground directly to the roof. There is no header cable or test box.

As the anodes decay, slough piles develop below. The slough piles are very slight (#237,241-244).

253-256) The drain exits through the floor. The opening is clear.

DIVE / CORR, INC.

257-268) The inlet and outlet pipes have shroud covers. Both of the shrouds have a good coating. Close examination of photographs (#259-268) show that one shroud has lifted off the floor. Corrosion is not noted here at this time.

269-284) The overflow pipe is internal and exits through the floor. The pipe coating is in good condition. No notable defects were sighted. Some rust is noted at the contact line of the pipe to brace (#277).

Wall braces also appear to be in good condition. No corrosion was sighted.

285-290) There are two round manways and a clean-out door. All three are gasket covered and not inspectible. No trapped water pockets are seen.

291-294) There is one wash-down valve. Rust is noted at all bolts.

295-352) There are three plate courses plus a knuckle course. The top 5' feet was above water and has been previously described as being in good condition with two exceptions.

The below water coating is in good condition. Patches are found scattered over the surface. Rust points at patch sites are rare (#295). An estimated fifteen small rust points are seen scattered over the surface (#307,313,327).

353-378) The below water portion of the column pole coating is in good condition. Rust tubercles are rare and small where found (#355). No notable defects were sighted.

The bases appear stable and the coating is in good condition.

379-392) This tank has sacrificial anodes. In all cases, decomposition is very slight and all anodes are in near new condition.

For reference, several of the anodes show no sign of decay (#387).

DIVE / CORR, INC.

SUMMARY

LAS ALAMITAS

EXTERIOR WALLS - Good

EXTERIOR ROOF - Good

VENT - Securely attached.
Screening - Good

HATCH - Securely locked - West side.
Handrail - Good
Safety Cables - Two

INTERIOR ROOF - Good - two patches of light colored rust staining are seen on the inside faces of the two knuckle braces by the internal access ladder.

ABOVE WALLS - Top 5' - good

BELOW WALLS - An estimated 15 very small rust points were scattered over the surface. Pitting was less than 1/16" deep in all cases.

FLOOR - An estimated 10 very small rust points were scattered over the surface. Pitting was less than 1/16" deep in all cases.

SEDIMENT - Most of the floor is either bare or near bare. No measurable deposits. No foreign debris from vandalism was found.

Vandal Guard - Securely locked

LADDER - Int - Securely attached - good condition
SAFETY RAIL - None

DIVE / CORR, INC.

FLOAT - Good
Target - Indicator properly riding on the target board at this elevation.
Guide Wires - Good

OVERFLOW - Interior pipe - good

MANWAY #1 - Plate is gasket covered
MANWAY #2 - Plate is gasket covered
CLEAN-OUT DOOR - Plate is gasket covered

DRAIN - Clear - exits through the floor.

COLUMNS - Good

INLET - Clear - good coating condition.
Flex Couple - Yes

OUTLET - Shroud coating is in good condition - front legs have lifted off the floor. No rust is seen at these sites.
Flex Couple - No

TELEMETRY PIPE - None

CATHODIC SYST
Hand Hole Covers Yes - good condition
Grommets Yes - added at the end of the inspection
Anodes Near new condition
Potentials taken by this inspector using a portable copper copper sulfate reference cell.
TOP -1.278 mVolts
MID -1.282 mVolts
BOT -1.305 mVolts




DIVE / CORR, INC.


RECOMMENDATIONS


- 1) Externally, the tank coating is in good condition and no action is recommended.
- 2) Internally, the coating is also in good condition. The only area of above water corrosion found was on two knuckle braces by the internal access ladder.




Underwater corrosion is rare and rust tubercles are small where found. Pitting was less than 1/16" deep in all cases. This is referred to engineering for review.





- 3) Re-inspect in three years.
- 4) Take potentials annually.


















DIVE / CORR, INC.

Industrial Photography & Inspection Services

P. O. BOX 30427 • LONG BEACH, CA 90853 • OFFICE (562) 439-8287 • FAX (562) 438-7151

TANK INSPECTION REPORT

AGENCY	La Puente CWD	DATE INSPECTED	8/03/17
SUPERVISOR	Mr. Greg Galindo	TANK NAME	East
SIZE	2.50 MG	HATCH	West
INSPECTOR	Dan Gross	DATE BUILT	1978
LADDER	Yes/Int-Yes/Ext	TENDER	F Echandi
BRIEF	General Survey	CP	Yes/Sac
		LAST INSPECTED	NA

CITY OF INDUSTRY

EAST TANK

THE FOLLOWING PHOTOGRAPHS CORRESPOND TO NUMBERS VIEWED AT THE BOTTOM OF THE ALBUM PAGES WHEN THE ALBUM IS VIEWED IN CENTERFOLD MODE:

13-14) City of Industry - East Tank. This is an above ground welded steel reservoir, four plate courses plus a knuckle course tall. The lowest course is referred to as course #1.

There are two tanks on this site. The East Reservoir is the tank with the access stairway and is closest to the site access gate.

15-16) The tank nameplate is above the round manway shown in photograph (#17).

FABRICATOR	-	AMERICAN BRIDGE
CONTRACT #	-	K9310
YEAR BUILT	-	1978
HEIGHT	-	36'5"
WIDTH	-	110'
SIZE	-	2.5 MG

DIVE / CORR, INC.

17-44) The exterior wall coating is in good condition. Rust along the edge of the floor plate extension (#27) is considered rare.

This tank has two round manways (#17,29). A transfer pipe (#41) is present. There are flexible couples.

The overflow exits through course #1 (#43). The end has a duckbill.

The exterior target is properly indicating water level (#21). The tank had 32' at the time of inspection.

There is one stairway (#37) and a walkway that connects the two tanks.

The tank has a concrete retaining ring. No significant defects were sighted. This tank does not have anchor bolts.

45-82) The exterior roof coating is in good condition. No notable defects were sighted.

The vent hood (#49-56) is secure. Rust is evident on the screen.

A sacrificial anode Cathodic Protection System has been added. Hand hole covers are in good condition. Grommets were added at the end of the inspection.

The roof access hatch (#77) was found properly locked. For the purposes of this report, the hatch will be referred to as being on the West side.

This tank has both handrail and safety cables. These appear to be in good condition.

83-90) The above water portion of the interior access ladder and telemetry pipe is secure and the coating is in good condition.

DIVE / CORR, INC.

91-94) The above water portion of the overflow funnel appears securely attached and in overall good condition. The adjacent shell and roof coating are in good condition.

95-98) The float is properly connected to the two guide wires as well as the traveling wire. The pan appears to move properly with a change in elevation.

99-128) There are four plate courses plus a knuckle course. The top 5' are above water. The above water walls are in good condition. No notable defects were sighted.

Beam ends are bolted to welded knuckle braces. All beams appear properly coated, upright and securely attached.

There are two fasteners per beam. Fasteners are in good condition.

129-190) The roof underside coating is in good condition. No notable defects were sighted. Patches are in good condition (#167,173).

All wiring for the Impressed Current Cathodic Protection System appears to be intact. No loose or fallen strings were identified. These were not pull tested. All anode wires are connected to the roof (#129).

All beams appear upright and securely attached. No gross bending or twisting was sighted.

The columns appear upright and stable. No indications of movement were observed. The above water column coating is in good condition.

191-202) The below water portion of the internal access ladder appears securely attached and in good condition.

Close examination of photographs (#197-202) that the at this water elevation, the two ladder base clips have detached from the floor. The gap is estimated at 1/4".

DIVE / CORR, INC.

The ladder has a safety climb rail. This also appears securely attached and in good condition.

203-204) The guide wires are securely attached and in good condition. Sediment seen here is considered typical and barely covers the floor.

205-216) A telemetry pipe is adjacent to the internal access ladder. The coating is in good condition. Of note is that there are two slots cut into the base (#207).

Small coating blisters are seen in very sparse numbers along the cut-out edge (#209) on both sides. Half of the blister caps are broken. Rust is not associated with this condition.

A transducer is not evident internally.

217-218) The drain exits through the floor. The opening is clear.

219-252) The floor coating is in good overall condition. Many patches are seen. Patches are in good condition.

Sediment is null and barely covers the floor. No measurable deposits were found. No foreign debris from vandalism was sighted.

This tank has sacrificial anodes. The anodes ground directly to the roof. There is no header cable or test box.

As the anodes decay, slough piles develop below (#237). The slough pile depths vary from moderate (#237) to very slight (#239).

253-256) The inlet/outlet is common and enters though course #1. The coating is in good condition. The adjacent shell coating is typical and in good condition.

DIVE / CORR, INC.

257-272) The overflow pipe is internal and exits through course #1. The pipe coating is in good condition. No notable defects were sighted.

Wall braces also appear to be in good condition. No corrosion was sighted.

273-284) There are two round manways. The plates in both cases are in good condition. Patches are in good condition (#279).

Corrosion at support hardware is minimal (#275-278).

285-318) There are four plate courses plus a knuckle course. The top 5' feet was above water and has been previously described as being in good condition.

The below water coating is in good condition. Patches are found scattered over the surface. These appear to be in good condition. No notable corrosion was seen.

319-342) The below water portion of the column pole coating is in good condition. No notable defects were sighted.

The bases appear stable and the coating is in good condition.

343-354) This tank has sacrificial anodes. In all cases, decomposition is very slight and all anodes are in near new condition.

For reference, several of the anodes show no sign of decay (#345,353).

DIVE / CORR, INC.

SUMMARY EAST TANK

EXTERIOR WALLS	-	Good
EXTERIOR ROOF	-	Good
VENT	-	Securely attached.
Screening	-	Rusting
HATCH	-	Securely locked - West side.
Handrail	-	Good
Safety Cables	-	Two
INTERIOR ROOF	-	Good
ABOVE WALLS	-	Top 5' - good
BELOW WALLS	-	Good
FLOOR	-	Good
SEDIMENT	-	Most of the floor is either bare or near bare. No measurable deposits. No foreign debris from vandalism was found.
STAIRS - Ext	-	Good
Vandal Guard	-	Securely locked.
LADDER - Int	-	Securely attached - good condition
SAFETY RAIL	-	Good
FLOAT	-	Good
Target	-	Indicator properly riding on the target board at this elevation.
Guide Wires	-	Good
OVERFLOW	-	Interior pipe - good
MANWAY #1	-	Good - some rust is seen on the support hardware.

DIVE / CORR, INC.

MANWAY #2 - Good

DRAIN - Clear - exits through the floor.

COLUMNS - Good

INLET - Clear - good coating condition.
Flex Couple - Yes

OUTLET - Same as the inlet.

TELEMETRY PIPE - Good - sparse number of coating blisters by the floor cut-out. No related corrosion.

CATHODIC SYST

Hand Hole Covers Yes - good condition

Grommets Yes - added at the end of the inspection

Anodes Near new condition

Potentials taken by this inspector using a portable copper copper sulfate reference cell.

TOP -1.283 mVolts




MID -1.271 mVolts




BOT -1.336 mVolts




DIVE / CORR, INC.




RECOMMENDATIONS





- 1) Externally, the tank coating is in good condition and no action is recommended.
- 2) Internally, the coating is also in good condition. No corrosion issues are observed at this time.
- 3) This tank has an internal telemetry pipe. There are two small openings at the base and water exchange appears poor. In addition, the sacrificial anodes cannot protect all of the interior surfaces. Consider removing this pipe at the next maintenance cycle.
- 4) The roof vent screen is rusting. Anticipate that this will need changing in one year.
















APPENDIX D

Reservoir Data Sheets

State of California

State Water Resources Control Board, Division of Drinking Water

Reservoir Data*(Use For All Distribution Storage, Chlorine Contact Tanks, Etc)*

System Name:	City of Industry Waterworks System
System Number:	1910029
Source of Information:	System Records
Collected By:	Roy Frausto
Date:	10/15/2018
Reservoir Number Or Name:	Lomitas
Location	Lomitas Ave.
Cross Streets:	Lomitas Ave. and S 4th Ave.
Neighborhood:	Residential/Equisterian
Size Of Lot:	N/A
Fencing:	Iron Fencing
Construction	
Date Constructed/Refurbished:	1986
Purpose (Storage, Chlorine Contact, Etc.):	Storage
Design Capacity (MG):	2.5
Operating Capacity (MG):	
Construction Type:	Steel
Shape:	Round
Construction Materials:	Steel
Sides:	Steel
Floor:	Steel
Cover Or Roof:	Steel
Interior Coating Type:	Epoxy
Dimensions	
Dimensions (H x L x W) Or (H & Diameter)(feet):	29' Height x 120" Diameter
Tank Bottom Elevation (feet):	393'
Height Of Tank (feet):	29'
Surface Drainage To Reservoir Possible?	No
Ventilation	
Screened (Y/N):	Yes
Cathodic Protection:	Yes
Inlet Description	
Distance Above Bottom (feet):	1/2'
Receives Water From:	San Gabriel Valley Water Company
Outlet Description	
Distance From Inlet (feet):	120'
Distance Above Bottom (feet):	1'
Delivers Water To:	Lomitas Pump Station
Pressure Zone Served:	CIWS Zone 1
Drain Location	
Distance Above Floor (feet):	Floor bottom
Discharge Location:	Catch Basin
Overflow Location	
Overflow Elevation (feet):	420'
Distance Above Bottom (feet):	27'
Discharge Location:	Catch Basin

State of California

State Water Resources Control Board, Division of Drinking Water

Reservoir Data (Cont'd)**If Hydropneumatic Tank**

Capacity (gal):	15,000
Site Glass:	
Air Vent:	No
Pressure Gage:	Yes

Comments

State of California

State Water Resources Control Board, Division of Drinking Water

Reservoir Data

(Use For All Distribution Storage, Chlorine Contact Tanks, Etc)

System Name:	City of Industry Waterworks System		
System Number:	1910029		
Source of Information:	System Records		
Collected By:	Roy Frausto	Date:	10/15/2018
Reservoir Number Or Name:	Industry East Tank		
Location	Industry Hills		
Cross Streets:	N/A		
Neighborhood:	Residential/Golf Course		
Size Of Lot:	N/A		
Fencing:	Manned Security Gate		
Construction			
Date Constructed/Refurbished:	1978		
Purpose (Storage, Chlorine Contact, Etc.):	Storage		
Design Capacity (MG):	2.5		
Operating Capacity (MG):			
Construction Type:	Steel		
Shape:	Round		
Construction Materials:	Steel		
Sides:	Steel		
Floor:	Steel		
Cover Or Roof:	Roof		
Interior Coating Type:	Epoxy		
Dimensions			
Dimensions (H x L x W) Or (H & Diameter)(feet):	36'5" Height x 110" Diameter		
Tank Bottom Elevation (feet):	744'		
Height Of Tank (feet):	36'5"		
Surface Drainage To Reservoir Possible?	No		
Ventilation			
Screened (Y/N):	Yes		
Cathodic Protection:	Yes		
Inlet Description			
Distance Above Bottom (feet):	2'		
Receives Water From:	Industry Hills Pump Station(s)		
Outlet Description			
Distance From Inlet (feet):	Same Inlet/Outlet		
Distance Above Bottom (feet):	2'		
Delivers Water To:	Industry Hills		
Pressure Zone Served:	Industry Hills Upper and Lower Zone		
Drain Location			
Distance Above Floor (feet):	In floor		
Discharge Location:	Catch Basin		
Overflow Location			
Overflow Elevation (feet):	778'		
Distance Above Bottom (feet):	34'		
Discharge Location:	Catch Basin		

State of California

State Water Resources Control Board, Division of Drinking Water

Reservoir Data (Cont'd)

If Hydropneumatic Tank

Capacity (gal):	
Site Glass:	
Air Vent:	
Pressure Gage:	

Comments

State of California		State Water Resources Control Board, Division of Drinking Water	
Reservoir Data			
<i>(Use For All Distribution Storage, Chlorine Contact Tanks, Etc)</i>			
System Name:	City of Industry Waterworks System		
System Number:	1910029		
Source of Information:	System Records		
Collected By:	Roy Frausto	Date:	10/15/2018
Reservoir Number Or Name:	Industry West Tank		
Location	Industry Hills		
Cross Streets:	N/A		
Neighborhood:	Residential//Golf Course		
Size Of Lot:	N/A		
Fencing:	Manned Security Gate		
Construction			
Date Constructed/Refurbished:	1978		
Purpose (Storage, Chlorine Contact, Etc.):	Storage		
Design Capacity (MG):	2.5		
Operating Capacity (MG):			
Construction Type:	Steel		
Shape:	Round		
Construction Materials:	Steel		
Sides:	Steel		
Floor:	Steel		
Cover Or Roof:	Steel		
Interior Coating Type:	Epoxy		
Dimensions			
Dimensions (H x L x W) Or (H & Diameter)(feet):	36'5" Height x 110" Diameter		
Tank Bottom Elevation (feet):	744'		
Height Of Tank (feet):	36'5"		
Surface Drainage To Reservoir Possible?	No		
Ventilation			
Screened (Y/N):	Yes		
Cathodic Protection:	Yes		
Inlet Description			
Distance Above Bottom (feet):	2'		
Receives Water From:	Industry Hills Pump Station(s)		
Outlet Description			
Distance From Inlet (feet):	Same Inlet/Outlet		
Distance Above Bottom (feet):	2'		
Delivers Water To:	Industry Hills		
Pressure Zone Served:	Industry Hills Upper and Lower Zone		
Drain Location			
Distance Above Floor (feet):	In floor		
Discharge Location:	Catch Basin		
Overflow Location			
Overflow Elevation (feet):	778'		
Distance Above Bottom (feet):	34'		
Discharge Location:	Catch Basin		
State of California		State Water Resources Control Board, Division of Drinking Water	
Reservoir Data (Cont'd)			
If Hydropneumatic Tank			
Capacity (gal):			
Site Glass:			
Air Vent:			
Pressure Gage:			
Comments			

APPENDIX E

Distribution Data Sheet

**STATE OF CALIFORNIA
DIVISION OF DRINKING WATER
DISTRIBUTION DATA SHEET**

System Name: City of Industry Waterworks System
Source of Information:
Collected By: Roy Frausto

No.: 1910029
Date: October 15, 2018

Number of Service Connections	1884
Pressure Range	40 - 115 psi
Type of Pipe Installed (%)	
Steel-Tar Coated & Wrapped	0%
Steel-Cemented Lined, Cement Coated	0%
Steel-Cement Lined	16%
Ductile Iron	9%
Asbestos Cement	73%
Galvanized	0%
Cast Iron	0%
PVC	2%
ABS	0%
Polyethylene (PE)	0%
Minimum Size of New Mains	6"
Amount Less Than 4" Diameter	8%
Condition of Mains	Good
Minimum Depth of Cover (Inches)	36
Service Connections (%)	
Copper	84%
Steel	5%
Plastic (Type & %)	PVC (1%) Poly (10%)
Lead	0%
Distance of Mains from Sewers	> 10 ft
Disinfection Method -- New Mains (Describe Procedure)	Per AWWA C651-14 Using the continuous feed method, sodium hypochlorite is injected into new water mains at a minimum of 50 PPM. Chlorine residual tests are taken at appropriate points to verify residual levels. Chlorinated water remains in the water mains for retention of 24 hours.
Disinfection After Repairs (Describe Procedure)	Per AWWA C651-14 Swab with hypochlorite solution and bacteriological testing
Infiltration Hazard (Relation to Groundwater Table)	
Dead Ends	
How Many?	65
Flushing Valves Installed?	Yes
Flushing Program (Describe)	During a flushing event, the field operator will record two chlorine residual results; one at the beginning of the flush and the other at the end. This will ensure that the target

and the color at the end. This will ensure that the target chlorine residual is maintaining in the system. If the initial chlorine residual is below 0.2 mg/l, this is an indication that the area needs to be flushed on a more frequent basis. In addition, the field operator will note the color (if any) and levels of sand (if any) observed in the discharged water at the beginning and end of the flush on the Flushing Report Form (Form). To ensure adequate flushing of dead-ends, the field operator should, at a minimum, flush 2 length volumes of the water main from the point of discharge to the last service under clear water discharge conditions. Under colored water discharge conditions, the field operator should flush until clear water discharge conditions are stable for a minimum of 2 minutes. Flushing documents are kept on file at La Puente Valley County Water District's main office at 112 N First St. in the City of La Puente, CA 91744.

Growth and Sludge in Mains	No
Valves	
Sufficient Number	Yes
Valve Maps Maintained	Yes
Valve Exercise Program	Yes
Cross Connection Control Program (Describe)	Administered in house by Mr. Cesar Ortiz. Cross connection surveys completed every 4 years.
Defects and Remarks	

APPENDIX F
Well Data Sheet

WELL DATA SHEET

Complete as much information as possible. Leave blank if information is not available, use N.A. if not applicable.

* Indicates items required for Source Water Assessment

** Indicates additional items required for assessments and Ground Water Rule

	(separate multiple entries in field with semi-colon)	Actual, Estimated or Default?
DATA SHEET GENERAL INFORMATION		
System Name	Industry Waterworks System	from DHS database
System Number	1910029	from DHS database
Source of Information (well log, DHS/County files, system, etc)	Well Log, System	
Organization Collecting Information (DHS, County, System, other)	CIWS System	
Date Information Collected/Updated	October 15, 2018	
WELL IDENTIFICATION		
* Well Number or Name	Well 05	from DHS database
* DHS Source Identification Number (FRDS ID No.)	1910029-007	
DWR Well Log on File? ("YES" or "NO")	Yes	
State Well Number (from DWR)	01S/11W-26P08 S	
Well Status (Active, Standby, Inactive)	Active	from DHS database
WELL LOCATION		
Latitude	34.05027778	from DHS database
Longitude	118.00444444	from DHS database
Ground Surface Elevation (ft above Mean Sea Level)	285	Estimated
Street Address	285 San Fidel Avenue	
Nearest Cross Street	Proctor Street	
City	La Puente	
County	Los Angeles	
* Neighborhood/Surrounding Area (see Note 1)	Re; A	
Site plan on file? ("YES" or "NO")	Yes	
DWR Ground Water Basin	Main San Gabriel	to come from DWR
DWR Ground Water Sub-basin	None	to come from DWR
SANITARY CONDITIONS		
** Distance to closest Sewer Line, Sewage Disposal, Septic Tank (ft)	90	Estimated
Distance to Active Wells (ft)	140	Estimated
Distance to Abandoned Wells (ft)	320	Actual
Distance to Surface Water (ft)	840	Estimated
** Size of controlled area around well (square feet)	105,000	Actual
* Type of access control to well site (fencing, building, etc)	Blk. Wall; Fencing; Bldg	
* Surface Seal? (Concrete slab)("YES", "NO" or "UNKNOWN")	Yes	
* Dimensions of concrete slab: Length(ft)/ Width(ft)/ Thick(in)	13/15/6	Actual
* Within 100 year flood plain? ("YES", "NO" or "UNKNOWN")	No	
* Drainage away from well? ("YES" or "NO")	Yes	
ENCLOSURE/HOUSING		
Enclosure Type (building, vault, none, etc.)	Building	
Floor material	Concrete	
Located in Pit? ("YES" or "NO")	No	
Pit depth (feet) (if applicable)	Not Applicable	
WELL CONSTRUCTION		
Date drilled	October 1984	Actual
Drilling Method	Reverse Rotary	Actual
Depth of Bore Hole (feet below ground surface)	980	Actual
Casing Beginning Depth/Ending Depth(ft below surface); 2nd Casing Beginning Depth/Ending Depth; 3rd Casing, etc.	0/830	Actual
Casing Diameter (inches); 2nd Casing Diameter; 3rd Casing, etc.	20	Actual

WELL DATA SHEET

	<i>(separate multiple entries in field with semi-colon)</i>	Actual, Estimated or Default?
WELL CONSTRUCTION (continued)		
Casing Material; 2nd Casing Material; 3rd Casing, etc.	Steel	Actual
Conductor casing used? ("YES", "NO" or "UNKNOWN") (See Note 2)	Yes	
Conductor casing removed? ("YES", "NO" or "UNKNOWN")	Unknown	
* Depth to highest perforations/screens (ft below surface) (or "UNKNOWN")	380	Actual
Screened Interval Beginning Depth/Ending Depth (ft below surface); 2nd Screened Interval Beg. Depth/Ending Depth; 3rd Screened Interval, etc.	380/810	Actual
* Total length of screened interval (ft) (default = 10% pump capacity in gpm) (or "UNKNOWN")	430	Actual
* Annular Seal? ("YES", "NO" or "UNKNOWN") (See Note 3)	Yes	Actual
* Depth of Annular Seal (ft)	230	Actual
Material of Annular Seal (cement grout, bentonite, etc.)	Cement Grout	Actual
Gravel pack, Depth to top (ft below ground surface)	300	Actual
Total length of gravel pack (ft)	530	Actual
AQUIFER		
* Aquifer Materials (list all that apply: sand, silt, clay, gravel, rock, fractured rock)	Sand, Gravel, Clay, Cobbles	Actual
* Effective porosity (decimal percent) (default = 0.2) (or "UNKNOWN")	0.2	Default
* Confining layer (Impervious Strata) above aquifer? ("YES", "NO" or "UNKNOWN")	No	Actual
Thickness of confining layer, if known (ft)	Not Applicable	
Depth to confining layer, if known (ft below ground)	Not Applicable	
* Static water level (ft below ground surface)	125	Measured
Static water level measurement: Date/Method	July 2018; Sounder	
Pumping water level (ft below ground surface)	139	Estimated
Pumping water level measurement: Date/Method	July 2018; Sounder	
WELL PRODUCTION		
Well Yield (gpm)	1,030	Actual
Well Yield Based On (i.e., pump test, etc.)	Pump Test	Actual
Date measured	4/23/2015	Actual
Is the well metered? ("YES" or "NO")	Yes	
Production (gallons per year)	550,000,000	Estimated
Frequency of Use (hours/year)	8,760	Estimated
Typical pumping duration (hours/day)	24	Estimated
PUMP		
Make	Peerless	
Type	Turbine	
Size (hp)	200	
* Capacity (gpm)	1,200	Actual
Depth to suction intake (ft below ground surface)	138	Actual
Lubrication Type	Oil	
Type of Power: (i.e., electric, diesel, etc.)	Electric	
Auxiliary power available? ("YES" or "NO")	No	
Operation controlled by: (i.e., level in tank, pressure, etc.)	Tank Level at Plant B5	
Pump to Waste capability? ("YES" or "NO")	Yes	
Discharges to: (i.e., distribution system, storage, etc.)	B5 Treatment Plant	
REMARKS AND DEFECTS (use additional sheets as necessary)		
Original well design is 2,500 gpm. Pump downsized in 2008 from 2,500 gpm to 1,200 gpm		

WELL DATA SHEET

NOTES

1. Neighborhood/Surrounding Area (list all that apply): A= Agricultural, Ru = Rural, Re = Residential, Co = Commercial, I = Industrial, Mu = Municipal, P = Pristine, O = Other
2. Conductor Casing - Oversized casing used to stabilize bore hole during well construction. Should be removed during installation of annular seal.
3. Annular Seal - Seal of grout in the space between the well casing and the wall of the drilled hole. Sometimes called "sanitary seal".

APPENDIX G

Booster Station Data Sheets

BOOSTER STATION DATA

System Name: City of Industry Waterworks System **System No.:** 1910029

Source of Information: System Records

Collected By: Roy Frausto **Date:** 10-15-18

Number or Name	<i>Industry Hills Pump Station 1</i>		
Date Constructed			
Purpose (system pressure, standby, etc.)	System Pressure to Industry Hills Lower Zone		
Total Pumping Capacity (gpm)	4,400		
Location			
Specific Location (Cross Streets, etc)	Hill Street and Del Valle Avenue		
Neighborhood	Residential /Golf Course		
Size of Lot	N/A		
Enclosure:			
Type	Block Building		
Floor	Concrete		
Insulation	None		
Heating	None		
Drainage	Ground Slope		
Flood Alarm	None		
Flood Hazard	None		
Relation to System			
Receives Water From	Lomitas Pump Station (CIWS Zone 1)		
Delivers Water To	Industry Hills Lower Zone		
Portable Pump Connections Available	None		
Station has Capacity to Reduce Pressure From High Side to Low Side of Booster	Yes		
Standby Power Available on Site	No		
Portable Standby Generator Connection Available	No		
Instrumentation and Control	SCADA and Hand Off Auto (HOA) Controls		
Pumping Units	<i>Booster 1</i>	<i>Booster 2</i>	<i>Booster 3</i>
Make	VERTI-LINE , AURORA PUMP CO.	VERTI-LINE , AURORA PUMP CO.	VERTI-LINE , AURORA PUMP CO.
Capacity	1,100 GPM	1,100 GPM	2,200 GPM
Lubrication	Oil and Grease	Oil and Grease	Oil and Grease
Power	75 HP (Electric)	75 HP (Electric)	150 HP (Natural Gas)
Sewer or Other Hazardous Connections(s)	None	None	None
Defects and Remarks:			

BOOSTER STATION DATA

System Name: City of Industry Waterworks System **System No.:** 1910029

Source of Information: System Records

Collected By: Roy Frausto **Date:** 10-15-18

Number or Name	<i>Industry Hills Pump Station 2</i>		
Date Constructed			
Purpose (system pressure, standby, etc.)	System Pressure to Industry Hills Upper Zone		
Total Pumping Capacity (gpm)	4,400		
Location			
Specific Location (Cross Streets, etc)	BV Handorf		
Neighborhood	Residential/Golf Course		
Size of Lot	N/A		
Enclosure:			
Type	Block Building		
Floor	Concrete		
Insulation	None		
Heating	None		
Drainage	Ground Slope		
Flood Alarm	None		
Flood Hazard	None		
Relation to System			
Receives Water From	Industry Hills Lower Zone		
Delivers Water To	Industry Hills Upper Zone		
Portable Pump Connections Available	None		
Station has Capacity to Reduce Pressure From High Side to Low Side of Booster	Yes		
Standby Power Available on Site	No		
Portable Standby Generator Connection Available	No		
Instrumentation and Control	SCADA and Hand Off Auto (HOA) Controls		
Pumping Units	<i>Booster 1</i>	<i>Booster 2</i>	<i>Booster 3</i>
Make	VERTI-LINE, AURORA PUMP CO.	VERTI-LINE, AURORA PUMP CO.	VERTI-LINE, AURORA PUMP CO.
Capacity	1,100 GPM	1,100 GPM	2,200 GPM
Lubrication	Oil and Grease	Oil and Grease	Oil and Grease
Power	75 HP (Electric)	75 HP (Electric)	150 HP (Natural Gas)
Sewer or Other Hazardous Connections(s)	None	None	None
Defects and Remarks:			

BOOSTER STATION DATASystem Name: City of Industry Waterworks System System No: 1910029Source of Information: System RecordsCollected By: Roy Frausto Date: 10-15-2018

Number or Name	<i>Industry Hills Pump Station 3</i>		
Date Constructed			
Purpose (system pressure, standby, etc.)	Backup to Supply Industry Hills Zone		
Total Pumping Capacity (gpm)	3,900		
Location			
Specific Location (Cross Streets, etc)	Industry Hills Parkway and Azusa Ave.		
Neighborhood	Residential/Golf Course		
Size of Lot			
Enclosure:			
Type	Block Building		
Floor	Concrete		
Insulation	None		
Heating	None		
Drainage	Ground Slope		
Flood Alarm	None		
Flood Hazard	None		
Relation to System			
Receives Water From	LPVCWD Zone 2		
Delivers Water To	Industry Hills (Upper Zone)		
Portable Pump Connections Available	None		
Station has Capacity to Reduce Pressure From High Side to Low Side of Booster	No		
Standby Power Available on Site	No		
Portable Standby Generator Connection Available	No		
Instrumentation and Control	SCADA and Hand Off Auto (HOA) Controls		
Pumping Units	<i>Booster 1</i>	<i>Booster 2</i>	<i>Booster 3</i>
Make	VERTI-LINE, AURORA PUMP CO.	VERTI-LINE, AURORA PUMP CO.	VERTI-LINE, AURORA PUMP CO.
Capacity	600 GPM	1100 GPM	2200 GPM
Lubrication	Oil and Grease	Oil and Grease	Oil and Grease
Power	40 HP (Electric)	60 HP (Electric)	150 HP (Natural Gas)
Sewer or Other Hazardous Connections(s)	None	None	None
Defects and Remarks:			

BOOSTER STATION DATA

System Name: City of Industry Waterworks System **System No:** 1910029

Source of Information: System Records

Collected By: Roy Frausto **Date:** 10-12-2018

Number or Name	<i>Lomitas Pump Station</i>		
Date Constructed			
Purpose (system pressure, standby, etc.)	System Pressure to CIWS Zone 1		
Total Pumping Capacity (gpm)	4,600		
Location			
Specific Location (Cross Streets, etc)	Lomitas Ave.		
Neighborhood	Residential/Equestrian		
Size of Lot	57,600 sqft.		
Enclosure:			
Type	Fenced Property		
Floor	Concrete		
Insulation	None		
Heating	None		
Drainage	Ground Slope		
Flood Alarm	None		
Flood Hazard	None		
Relation to System			
Receives Water From	Lomitas Reservoir		
Delivers Water To	CIWS Zone 1		
Portable Pump Connections Available	None		
Station has Capacity to Reduce Pressure From High Side to Low Side of Booster	No		
Standby Power Available on Site	Yes		
Portable Standby Generator Connection Available	Yes		
Instrumentation and Control	SCADA and Hand Off Auto (HOA) Controls		
Pumping Units	<i>Booster 1</i>	<i>Booster 2</i>	<i>Booster 3</i>
Make			
Capacity	1,200 GPM	1,600 GPM	1,600 GPM
Lubrication	Oil and Grease	Oil and Grease	Oil and Grease
Power	50 HP	100 HP	100 HP
Sewer or Other Hazardous Connections(s)	None	None	None
Defects and Remarks:			

BOOSTER STATION DATA

System Name: City of Industry Waterworks System **System No:** 1910029

Source of Information: System Records

Collected By: Roy Frausto **Date:** 10-15-2018

Number or Name	<i>Lake Loop Pump Station</i>		
Date Constructed			
Purpose (system pressure, standby, etc.)	Lake Loop Zone		
Total Pumping Capacity (gpm)	600		
Location			
Specific Location (Cross Streets, etc)	Lake Loop Rd.		
Neighborhood	Residential		
Size of Lot	N/A		
Enclosure:			
Type	Block Fencing		
Floor	Concrete		
Insulation	None		
Heating	None		
Drainage	Ground Slope		
Flood Alarm	None		
Flood Hazard	None		
Relation to System			
Receives Water From	Industry Hills (Upper Zone)		
Delivers Water To	Lake Loop Zone		
Portable Pump Connections Available	None		
Station has Capacity to Reduce Pressure From High Side to Low Side of Booster	No		
Standby Power Available on Site	No		
Portable Standby Generator Connection Available	No		
Instrumentation and Control	SCADA and Hand Off Auto (HOA) Controls		
Pumping Units	<i>Booster 1</i>	<i>Booster 2</i>	<i>Booster 3</i>
Make	GRUNDFOS	GRUNDFOS	GRUNDFOS
Capacity	200 GPM	200 GPM	200 GPM
Lubrication	Grease	Grease	Grease
Power	10 HP (Electric)	10 HP (Electric)	10 HP (Electric)
Sewer or Other Hazardous Connections(s)	None	None	None
Defects and Remarks:			

APPENDIX H

Cross-Connection Control Program Evaluation

STATE OF CALIFORNIA
WATER RESOURCES CONTROL BOARD
DIVISION OF DRINKING WATER
HOLLYWOOD DISTRICT OFFICE
CROSS-CONNECTION CONTROL SURVEY

SYSTEM NAME: City of Industry Waterworks System NUMBER: 1910029

NAME OF PERSON FILING REPORT: Roy Frausto

POSITION: Engineering & Compliance Manager

I. GENERAL

A. Do you have an active Cross-Connection Control Program? Yes X No _____

B. How is the program administered?

In house (X)
By contract with water supplier (wholesaler) ()
Coordinated with local agency ()
Other _____ ()

C. Do you have a copy of the GUIDANCE MANUAL FOR CROSS CONNECTION CONTROL PROGRAMS (ODW GREEN BOOK)? Yes X No _____

USC Manual for Cross Connection Control

II. ELEMENTS OF A CROSS-CONNECTION CONTROL PROGRAM

A. ORDINANCE OR RULES OF SERVICE

1. Have you adopted an enforceable Cross-Connection Control ordinance or rules of service? Yes X No _____

Attach a copy of the ordinance or rules when you return this survey.

2. Are users who are in non-compliance with the cross-connection policy, given written notice to make corrections? Yes X No _____

3. Describe procedures followed when corrections are not made: Procedures are followed according to District Ordinance

B. CROSS-CONNECTION SURVEYS

1. Have you conducted a survey of your users to determine specific cross-connection control requirements and problems? Yes X No _____

2. Are premises periodically reevaluated for backflow hazard? Yes X No _____

If yes, how is this accomplished? Cross

connection survey shutdown test every 4 years

3. Are new services reviewed to establish the need for backflow protection? Yes X No _____

4. Who does the reviewing and what procedures are followed? District Engineer checks plans and

CCC Specialists do site inspections

C. PROVISIONS FOR BACKFLOW PROTECTION

1. How is backflow protection provided?

- Premises isolation (X)
- Internal protection ()
- Combination ()

2. Who is responsible for installation of assemblies?

Water Purveyor (), The Water User (X), Both (), Neither (), Other _____ ()

3. If the user is responsible for installation of assemblies, do you provide them with a list of approved backflow assemblies? Yes X No _____

What is the source of that list? Website -

Los Angeles County list of approved backflow devices

4. Is the installation of approved backflow assemblies inspected by the purveyor to determine if they have proper clearance, drainage, and security as specified in Section 7603? Yes X No _____

D. PROGRAM MANAGEMENT

1. Do you have personnel with expertise and authority to conduct cross-connection surveys to carry out the cross-connection control program? Yes X No _____

<u>Name</u>	<u>Summary of Education, Training and Experience</u>
a) <u>Cesar A. Ortiz</u>	<u>AWWA Cross Connection Control Specialist, T-3, D-3</u>
b) <u>Miguel Molina</u>	<u>AWWA Cross Connection Control Specialist, T-2, D-4</u>
c) _____	_____
d) _____	_____

E. ASSEMBLY TESTING AND MAINTENANCE

1. Are all backflow assemblies tested, at least, on an annual basis? Yes X No

Number of backflow assemblies in system 191
Number of backflow assemblies installed this year 6
Number of backflow assemblies tested this year 191

2. Do you employ certified backflow assembly testers? Yes No X

<u>Name</u>	<u>Certified By</u>	<u>Certificate #</u>
a) _____		
b) _____		
c) _____		
d) _____		

3. Backflow assemblies are tested by:

Water Purveyor (), The Water User (X),
Both (), Neither (), Other _____ ()

4. If the user is responsible for testing of assemblies, do you provide them with a list of certified testers? Yes X No

5. Backflow assemblies are maintained by:

Water Purveyor (), The Water User (X),
Both (), Neither (), Other _____ ()

6. Do you conduct follow-up inspections to determine compliance with testing and maintenance requirements? Yes X No

F. RECORDS

1. Do you maintain installation, inspection, and testing records? Yes X No


2. Have you established a program to evaluate inspection and testing records? Yes X No

III. DEGREE OF PROTECTION

Type of backflow protection required for premises with:

	N/A	AG ¹	RPP ²	DC ³	Other	None
Sewage treatment plants	(X)	()	()	()	()	()
Sewage lift stations	(X)	()	()	()	()	()
Reclaimed water systems	()	()	(X)	()	()	()
Irrigation systems						
Landscape	()	()	(X)	()	()	()
Agricultural	(X)	()	()	()	()	()
With chemical injection	(X)	()	()	()	()	()
Unapproved auxiliary water systems (i.e. wells, ponds, etc.)						
a) Interconnected with water system	(X)	()	()	()	()	()
b) separated from water system	(X)	()	()	()	()	()
Docks and piers	(X)	()	()	()	()	()
Industrial plants with internal hazards	()	()	(X)	()	()	()
Hospitals and clinics	()	()	(X)	()	()	()
Laboratories	()	()	(X)	()	()	()
Premises with restricted access	()	()	(X)	()	()	()
Fire system connected to water system						
a) With unapproved water supply on premise but not interconnected	(X)	()	()	()	()	()
b) Connected to public water supply and interconnected to unapproved auxiliary supply	(X)	()	()	()	()	()
c) Supplies from water system with on-site private storage or fire pumps	(X)	()	()	()	()	()
Water trucks	(X)	()	()	()	()	()
Sewer flushing operations	(X)	()	()	()	()	()
Other	()	()	()	()	()	()

- 1 AG = Approved Air Gap
- 2 RPP = Reduced Pressure Principle Assembly
- 3 DC = Approved Double Check Valve Assembly

Signed: 
 Date: 7-23-18

If you need more space to answer any of the questions, please attach additional sheets.

APPENDIX E

Water Supply Permit

APPENDIX I

Water Supply Permit

State Water Resources Control Board
Division of Drinking Water

Certificate of Issuance
OF A

WATER SUPPLY PERMIT

TO

CITY OF INDUSTRY WATERWORKS SYSTEM

This is to certify that a water supply permit **04-07-18P-002** has been issued to City of Industry Waterworks System on **November 15, 2018**, to supply water for domestic purposes to City of Industry Waterworks System. The permit was issued by the SWRCB - Division of Drinking Water, pursuant to the provisions of Division 104, Part 12, Chapter 4, Article 7, of the California Health and Safety Code. The permit is subject to the requirements of Title 22, California Code of Regulations, and to the conditions provided in the water supply permit.



A copy of the water supply permit is on file with City of Industry Waterworks System or may be obtained by contacting the Hollywood District Office of the SWRCB – Division of Drinking Water, Field Operations Branch, 500 N. Central Ave., Ste. 500, Glendale, CA 91203

A handwritten signature in blue ink, appearing to read "Dmitriy Ginzburg".

Dmitriy Ginzburg, P.E., Hollywood District Senior Sanitary Engineer